



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 16-Dec-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 15-Dec-20

(CHPH 5X50 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUs | REMARKS |
|----------|-----------|----------|-----------|----------|-------------|----------------|-------------------|--|
| 1 | 15-Dec-20 | 0:00:00 | 15-Dec-20 | 24:00:00 | 24:00:00 | 50.00 | 1.195 | Today (i.e. 16.12.2020), 3 SSP-CHPH M/cs are running at 10:00 hrs. |
| 2 | 15-Dec-20 | 0:00:00 | 15-Dec-20 | 24:00:00 | 24:00:00 | 51.00 | 1.199 | |
| 3 | 15-Dec-20 | 0:00:00 | 15-Dec-20 | 24:00:00 | 24:00:00 | 50.00 | 1.205 | |
| 4 | 15-Dec-20 | 0:00:00 | 15-Dec-20 | 0:00:00 | 0:00:00 | 0.00 | 0.000 | |
| 5 | 15-Dec-20 | 16:00:00 | 15-Dec-20 | 24:00:00 | 8:00:00 | 50.00 | 0.393 | |

(RBPH 6X200 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUs | REMARKS |
|----------|-----------|---------|-----------|----------|-------------|----------------|-------------------|---|
| 1 | 15-Dec-20 | 0:00:00 | 15-Dec-20 | 0:00:00 | 0:00:00 | 0 | 0.000 | Today(i.e. 16.12.2020), 3 SSP-RBPH M/c are running at 10:00 hrs. Unit No. 1 is under L/C from 01.12.2020 |
| 2 | 15-Dec-20 | 0:00:00 | 15-Dec-20 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 3 | 15-Dec-20 | 7:00:00 | 15-Dec-20 | 11:30:00 | 4:30:00 | 205 | 0.918 | |
| 4 | 15-Dec-20 | 6:45:00 | 15-Dec-20 | 11:45:00 | 5:00:00 | 204 | 1.022 | |
| 5 | 15-Dec-20 | 0:00:00 | 15-Dec-20 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 6 | 15-Dec-20 | 6:30:00 | 15-Dec-20 | 12:00:00 | 5:30:00 | 205 | 1.124 | |

| | CHPH (5 X 50MW) | RBPH (6X200 MW) | SSP(CHPH+RBPH) |
|--|-----------------|-----------------|----------------|
| GROSS GENERATION IN(MUs) | 3.992 | 3.064 | 7.056 |
| CUMMULATIVE GROSS GEN. FOR MONTH (MUs) | 69.416 | 48.898 | 118.314 |
| PREVIOUS DAY ACTUAL RUNNING HOURS | 80:00:00 | 15:00:00 | |
| TODAY'S DC (Schedule) Planned (in Hours) | 72:00:00 | 15:00:00 | |
| DAY AHEAD (TOMMORROW) DC (in Hours) | 72:00:00 | 15:00:00 | |

SSP hydrological data : at 08:00 Hrs on 16-Dec-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 134.61 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 29616 Cusec 72.46 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 20266 Cusec 49.58 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

| HR | GODBOLE |
|-------|---------|
| 15753 | 0 |

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

| GODBOLE | OVER FLOW | HR | CHPH | RBPH | Ev. Loss |
|---------|-----------|-------|-------|------|----------|
| 620 | 0 | 15753 | 15771 | 4495 | 479 |



जल संचयन - जल संरक्षण

AEE (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Dhule-1 Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Details:

Unit No.6: 19:40 Hrs on 15.12.2020 to 05:40 Hrs on 16.12.2020.

Unit No.4: 19:50 Hrs on 15.12.2020 to 05:35 Hrs on 16.12.2020.