



DAILY PLANT REPORT (DPR) OF Sardar Sarovar Project Power Houses
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 21-Dec-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 20-Dec-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	20-Dec-20	0:00:00	20-Dec-20	24:00:00	24:00:00	50.00	1.193	Today (i.e. 21.12.2020), 3 SSP-CHPH M/cs are running at 10:00 hrs.
2	20-Dec-20	0:00:00	20-Dec-20	24:00:00	24:00:00	51.00	1.205	
3	20-Dec-20	0:00:00	20-Dec-20	24:00:00	24:00:00	50.00	1.203	
4	20-Dec-20	0:00:00	20-Dec-20	0:00:00	0:00:00	0.00	0.000	
5	20-Dec-20	0:00 10:00	20-Dec-20	3:30 24:00	17:30:00	50.00	0.874	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	20-Dec-20	0:00:00	20-Dec-20	0:00:00	0:00:00	0	0.000	Today(i.e. 21.12.2020), 3 SSP-RBPH M/c are running at 10:00 hrs.
2	20-Dec-20	0:00:00	20-Dec-20	0:00:00	0:00:00	0	0.000	
3	20-Dec-20	0:00:00	20-Dec-20	0:00:00	0:00:00	0	0.000	
4	20-Dec-20	6:30:00	20-Dec-20	11:30:00	5:00:00	204	1.024	
5	20-Dec-20	6:45:00	20-Dec-20	11:45:00	5:00:00	203	1.022	
6	20-Dec-20	7:00:00	20-Dec-20	12:00:00	5:00:00	204	1.020	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	4.475	3.066	7.541
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	89.704	64.204	153.908
PREVIOUS DAY ACTUAL RUNNING HOURS	89:30:00	15:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	15:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 21-Dec-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 134.59 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 4171 Cusec 10.20 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 21428 Cusec 52.43 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
17818	625

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
619	0	18303	17006	4422	481



[Signature]
20/12/20
AEE (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Details:

Unit No.2: 20:00 Hrs on 20.12.2020 to 05:50 Hrs on 21.12.2020.

Unit No.3: 18:15 Hrs on 20.12.2020 to 05:55 Hrs on 21.12.2020.

Unit No.6: 18:20 Hrs on 20.12.2020 to 06:05 Hrs on 21.12.2020.

Unit No.4: 20:15 Hrs on 20.12.2020 to 06:00 Hrs on 21.12.2020.