



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

**DAILY PLANT REPORT (DPR) OF Sardar Sarovar Project Power Houses**  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 22-Dec-20  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 21-Dec-20

**(CHPH 5X50 MW)**

| Unit No. | START     |                   | STOP      |                      | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUs | REMARKS                                                            |
|----------|-----------|-------------------|-----------|----------------------|-------------|----------------|-------------------|--------------------------------------------------------------------|
| 1        | 21-Dec-20 | 0:00:00           | 21-Dec-20 | 24:00:00             | 24:00:00    | 51.00          | 1.197             | Today (i.e. 22.12.2020), 3 SSP-CHPH M/cs are running at 10:00 hrs. |
| 2        | 21-Dec-20 | 0:00:00           | 21-Dec-20 | 24:00:00             | 24:00:00    | 51.00          | 1.207             |                                                                    |
| 3        | 21-Dec-20 | 00:00:00<br>17:50 | 21-Dec-20 | 17:38:00<br>24:00:00 | 23:48:00    | 50.00          | 1.191             |                                                                    |
| 4        | 21-Dec-20 | 0:00:00           | 21-Dec-20 | 0:00:00              | 0:00:00     | 0.00           | 0.000             |                                                                    |
| 5        | 21-Dec-20 | 11:40:00          | 21-Dec-20 | 24:00:00             | 12:20:00    | 50.00          | 0.610             |                                                                    |

**(RBPH 6X200 MW)**

| Unit No. | START     |         | STOP      |          | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUs | REMARKS                                                          |
|----------|-----------|---------|-----------|----------|-------------|----------------|-------------------|------------------------------------------------------------------|
| 1        | 21-Dec-20 | 0:00:00 | 21-Dec-20 | 0:00:00  | 0:00:00     | 0              | 0.000             | Today(i.e. 22.12.2020), 3 SSP-RBPH M/c are running at 10:00 hrs. |
| 2        | 21-Dec-20 | 6:30:00 | 21-Dec-20 | 11:30:00 | 5:00:00     | 204            | 1.018             |                                                                  |
| 3        | 21-Dec-20 | 6:45:00 | 21-Dec-20 | 11:45:00 | 5:00:00     | 204            | 1.018             |                                                                  |
| 4        | 21-Dec-20 | 0:00:00 | 21-Dec-20 | 0:00:00  | 0:00:00     | 0              | 0.000             |                                                                  |
| 5        | 21-Dec-20 | 0:00:00 | 21-Dec-20 | 0:00:00  | 0:00:00     | 0              | 0.000             |                                                                  |
| 6        | 21-Dec-20 | 7:00:00 | 21-Dec-20 | 12:00:00 | 5:00:00     | 204            | 1.024             |                                                                  |

|                                          | CHPH (5 X 50MW) | RBPH (6X200 MW) | SSP(CHPH+RBPH) |
|------------------------------------------|-----------------|-----------------|----------------|
| GROSS GENERATION IN(MUs)                 | 4.205           | 3.060           | 7.265          |
| CUMMULATIVE GROSS GEN. FOR MONTH (MUs)   | 93.909          | 67.264          | 161.173        |
| PREVIOUS DAY ACTUAL RUNNING HOURS        | 84:08:00        | 15:00:00        |                |
| TODAY's DC (Schedule) Planned (in Hours) | 72:00:00        | 0:00:00         |                |
| DAY AHEAD (TOMMORROW) DC (in Hours)      | 72:00:00        | 15:00:00        |                |

SSP hydrological data : at 08:00 Hrs on 22-Dec-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 134.58 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 20196 Cusec 49.41 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 20983 Cusec 51.34 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

| HR    | GODBOLE |
|-------|---------|
| 18303 | 619     |

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

| GODBOLE | OVER FLOW | HR    | CHPH  | RBPH | Ev. Loss |
|---------|-----------|-------|-------|------|----------|
| 0       | 0         | 18305 | 16600 | 4383 | 479      |



*[Signature]*  
22/12/2020  
AEE (EMC)  
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 KV SSP Asoj, Kasor, Dhule-1, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Details:

Unit No.3: 19:45 Hrs on 21.12.2020 to 05:45 Hrs on 22.12.2020.

Unit No.6: 19:35 Hrs on 21.12.2020 to 05:50 Hrs on 22.12.2020.