



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 25-Dec-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 24-Dec-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	24-Dec-20	0:00:00	24-Dec-20	24:00:00	24:00:00	50.00	1.189	Today (i.e. 25.12.2020), 3 SSP-CHPH M/cs are running at 10:00 hrs.
2	24-Dec-20	0:00:00	24-Dec-20	24:00:00	24:00:00	51.00	1.208	
3	24-Dec-20	10:00:00	24-Dec-20	24:00:00	14:00:00	50.00	0.688	
4	24-Dec-20	0:00:00	24-Dec-20	24:00:00	24:00:00	51.00	1.212	
5	24-Dec-20	0:00:00	24-Dec-20	1:30:00	1:30:00	50.00	0.075	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	24-Dec-20	7:00:00	24-Dec-20	11:30:00	4:30:00	204	0.918	Today(i.e. 25.12.2020), 4 SSP-RBPH M/c are running at 10:00 hrs.
2	24-Dec-20	0:00:00	24-Dec-20	0:00:00	0:00:00	0	0.000	
3	24-Dec-20	6:45:00	24-Dec-20	11:45:00	5:00:00	205	1.018	
4	24-Dec-20	0:00:00	24-Dec-20	0:00:00	0:00:00	0	0.000	
5	24-Dec-20	0:00:00	24-Dec-20	0:00:00	0:00:00	0	0.000	
6	24-Dec-20	6:30:00	24-Dec-20	12:00:00	5:30:00	204	1.122	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	4.372	3.058	7.430
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	106.950	76.430	183.380
PREVIOUS DAY ACTUAL RUNNING HOURS	87:30:00	15:00:00	
TODAY's DC (Schedule) Planned (in Hours)	72:00:00	15:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	15:00:00	

SSP hydrological data : at 08:00 Hrs on 25-Dec-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 134.22 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 11867 Cusec 29.03 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 21533 Cusec 52.68 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
17914	613

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
616	0	17484	17113	4420	471



for Ascheta Karamga
AEE (EMC)
NCA, INDORE
25-12-2020

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1,Dhule-2 Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Details:

Unit No.6: 20:15 Hrs on 24.12.2020 to 05:50 Hrs on 25.12.2020.

Unit No.3: 20:25 Hrs on 24.12.2020 to 05:45 Hrs on 25.12.2020