



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 06-Dec-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 05-Dec-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	5-Dec-20	0:00:00	5-Dec-20	24:00:00	24:00:00	50.00	1.200	Today (i.e. 06.12.2020), 5 SSP-CHPH M/cs are running at 10:00 hrs.
2	5-Dec-20	0:00:00	5-Dec-20	24:00:00	24:00:00	51.00	1.203	
3	5-Dec-20	16:39:00	5-Dec-20	24:00:00	7:21:00	50.00	0.364	
4	5-Dec-20	0:00:00	5-Dec-20	16:55:00	16:55:00	51.00	0.852	
5	5-Dec-20	0:00:00	5-Dec-20	24:00:00	24:00:00	51.00	1.198	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	5-Dec-20	0:00:00	5-Dec-20	0:00:00	0:00:00	0	0.000	Today (i.e. 06.12.2020), 4 SSP-RBPH M/c are running at 10:00 hrs. Unit No. 1 is under L/C from 01.12.2020
2	5-Dec-20	0:00:00	5-Dec-20	0:00:00	0:00:00	0	0.000	
3	5-Dec-20	7:15:00	5-Dec-20	12:00:00	4:45:00	205	0.972	
4	5-Dec-20	6:30:00	5-Dec-20	11:15:00	4:45:00	204	0.978	
5	5-Dec-20	6:45:00	5-Dec-20	11:30:00	4:45:00	205	0.978	
6	5-Dec-20	7:00:00	5-Dec-20	11:45:00	4:45:00	204	0.972	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN (MUs)	4.817	3.900	8.717
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	24.062	11.676	35.738
PREVIOUS DAY ACTUAL RUNNING HOURS	96:16:00	19:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	96:00:00	19:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	19:00:00	

SSP hydrological data : at 08:00 Hrs on 6-Dec-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 134.60 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 35599 Cusec 87.10 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 24983 Cusec 61.12 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
20561	613

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
614	0	21357	19377	5606	479



Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
GoMP. Member(Power),NVDA,Bhopal
GoMah. CE,WRD, Mumbai
GoG CE(E&M),SSNNL,Vadoadra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Details:

Unit No.5: 19:10 Hrs on 05.12.2020 to 05:40 Hrs on 06.12.2020.

Unit No.6: 19:15 Hrs on 05.12.2020 to 05:45 Hrs on 06.12.2020.

AEE (EMC)
NCA, INDORE

Handwritten signature and date: 06/12/20