



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 08-Dec-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 07-Dec-20

(CHPH 5X50 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUs | REMARKS |
|----------|----------|----------------|----------|----------------|-------------|----------------|-------------------|--|
| 1 | 7-Dec-20 | 0:00:00 | 7-Dec-20 | 24:00:00 | 24:00:00 | 51.00 | 1.205 | Today (i.e. 08.12.2020), 4 SSP-CHPH M/cs are running at 10:00 hrs. |
| 2 | 7-Dec-20 | 0:00:00 | 7-Dec-20 | 24:00:00 | 24:00:00 | 50.00 | 1.192 | |
| 3 | 7-Dec-20 | 0:00:00 | 7-Dec-20 | 24:00:00 | 24:00:00 | 50.00 | 1.201 | |
| 4 | 7-Dec-20 | 01:00 18:00 | 7-Dec-20 | 08:00 21:30 | 10:30:00 | 50.00 | 0.525 | |
| 5 | 7-Dec-20 | 0:00:00 | 7-Dec-20 | 24:00:00 | 24:00:00 | 51.00 | 1.200 | |

(RBPH 6X200 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUs | REMARKS |
|----------|----------|---------|----------|----------|-------------|----------------|-------------------|---|
| 1 | 7-Dec-20 | 0:00:00 | 7-Dec-20 | 0:00:00 | 0:00:00 | 0 | 0.000 | Today(i.e. 08.12.2020), 4 SSP-RBPH M/c are running at 10:00 hrs. Unit No. 1 is under L/C from 01.12.2020 |
| 2 | 7-Dec-20 | 0:00:00 | 7-Dec-20 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 3 | 7-Dec-20 | 6:30:00 | 7-Dec-20 | 11:15:00 | 4:45:00 | 204 | 0.968 | |
| 4 | 7-Dec-20 | 7:15:00 | 7-Dec-20 | 11:30:00 | 4:15:00 | 204 | 0.872 | |
| 5 | 7-Dec-20 | 6:45:00 | 7-Dec-20 | 11:45:00 | 5:00:00 | 205 | 1.026 | |
| 6 | 7-Dec-20 | 7:00:00 | 7-Dec-20 | 12:00:00 | 5:00:00 | 205 | 1.026 | |

| | CHPH (5 X 50MW) | RBPH (6X200 MW) | SSP(CHPH+RBPH) |
|--|-----------------|-----------------|----------------|
| GROSS GENERATION IN(MUs) | 5.323 | 3.892 | 9.215 |
| CUMMULATIVE GROSS GEN. FOR MONTH (MUs) | 34.766 | 19.468 | 54.234 |
| PREVIOUS DAY ACTUAL RUNNING HOURS | 106:30:00 | 19:00:00 | |
| TODAY'S DC (Schedule) Planned (in Hours) | 96:00:00 | 19:00:00 | |
| DAY AHEAD (TOMMORROW) DC (in Hours) | 96:00:00 | 19:00:00 | |

SSP hydrological data : at 08:00 Hrs on 8-Dec-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 134.54 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 20979 Cusec 51.33 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 25569 Cusec 62.56 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

| HR | GODBOLE |
|-------|---------|
| 23021 | 627 |

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

| GODBOLE | OVER FLOW | HR | CHPH | RBPH | Ev. Loss |
|---------|-----------|-------|-------|------|----------|
| 0 | 0 | 21418 | 19845 | 5724 | 479 |



Shubh
AEE (EMC)
NCA, INDORE
8/12/2020

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Dhule-1Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Details:

Unit No.5: 18:20 Hrs on 07.12.2020 to 05:40 Hrs on 08.12.2020.

Unit No.6: 18:35 Hrs on 07.12.2020 to 05:45 Hrs on 08.12.2020.