



(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	1-Feb-18	9:30:00	1-Feb-18	24:00:00	14:30:00	20.00	0.289	Today(02.02.2018) Two SSP-CHPH units are running at 08:00hrs. SSP-CHPH Unit no. 3 is under AOH from dt. 16.01.2018
2	1-Feb-18	0:00:00	1-Feb-18	24:00:00	24:00:00	21.00	0.463	
3	1-Feb-18	0:00:00	1-Feb-18	0:00:00	0:00:00	0.00	0.000	
4	1-Feb-18	0:00:00	1-Feb-18	0:00:00	0:00:00	0.00	0.000	
5	1-Feb-18	0:00:00	1-Feb-18	20:30:00	20:30:00	21.00	0.415	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	1-Feb-18	0:00:00	1-Feb-18	0:00:00	0:00:00	0	0.000	Today(02.02.2018) No SSP-RBPH units are running at 08:00hrs. SSP-RBPH Unit no. 1 is under AOH from dt. 20.01.2018
2	1-Feb-18	0:00:00	1-Feb-18	0:00:00	0:00:00	0	0.000	
3	1-Feb-18	0:00:00	1-Feb-18	0:00:00	0:00:00	0	0.000	
4	1-Feb-18	0:00:00	1-Feb-18	0:00:00	0:00:00	0	0.000	
5	1-Feb-18	0:00:00	1-Feb-18	0:00:00	0:00:00	0	0.000	
6	1-Feb-18	0:00:00	1-Feb-18	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	1.167	0.000	1.167
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	1.167	0.000	1.167
PREVIOUS DAY ACTUAL RUNNING HOURS	59:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 2-Feb-18

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 122.32 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 2372 Cusec 6 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 10019 Cusec 25 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
8809	623

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH
635	0	8809	10019	0



AEB(EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE :i) All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

ii) SSP-RBPH SCO Mode Running Detail: RBPH Unit No.4 was in SCO Mode from 20:50hrs on 01.2.18 to 7:00hrs on 2.2.18.