



DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 13-Feb-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 12-Feb-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	12-Feb-19	0:00:00	12-Feb-19	24:00:00	24:00:00	31.00	0.733	Today (i.e. 13.02.2019), 3 CHPH M/c are running at 10:00 hrs.
2	12-Feb-19	0:00:00	12-Feb-19	0:00:00	0:00:00	0.00	0.000	
3	12-Feb-19	16:30:00	12-Feb-19	24:00:00	7:30:00	32.00	0.232	
4	12-Feb-19	0:00:00	12-Feb-19	24:00:00	24:00:00	31.00	0.765	
5	12-Feb-19	0:00:00	12-Feb-19	23:00:00	23:00:00	32.00	0.723	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	12-Feb-19	0:00:00	12-Feb-19	0:00:00	0:00:00	0	0.000	Today (i.e. 13.02.2019), no SSP-RBPH M/c is scheduled
2	12-Feb-19	0:00:00	12-Feb-19	0:00:00	0:00:00	0	0.000	
3	12-Feb-19	0:00:00	12-Feb-19	0:00:00	0:00:00	0	0.000	
4	12-Feb-19	0:00:00	12-Feb-19	0:00:00	0:00:00	0	0.000	
5	12-Feb-19	0:00:00	12-Feb-19	0:00:00	0:00:00	0	0.000	
6	12-Feb-19	0:00:00	12-Feb-19	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	2.453	0.000	2.453
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	29.306	0.000	29.306
PREVIOUS DAY ACTUAL RUNNING HOURS	78:30:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 13-Feb-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 118.09 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 12396 Cusec 30 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 16156 Cusec 40 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
15997	608

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
605	0	15052	16156	0	313



(Signature)

AEE (EMC)
NCA, INDORE

Copy to:

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member (Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG CE (E&M), SSNNL, Vadoadra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 KV SSP-Asoj, Kasor, Raj-2 and Dhule-2 lines are in service.

2. SSP SCO Running Details:

Unit No.2: 19:20 hrs on 12.02.19 to 06:45 hrs on 13.02.19.

Unit No.5: 19:30 hrs on 12.02.19 to 06:50 hrs on 13.02.19.