



DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 16-Feb-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 15-Feb-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	15-Feb-19	17:30:00	15-Feb-19	24:00:00	6:30:00	30.00	0.188	Today(i.e. 16.02.2019), 3 CHPH M/cs are running at 10:00 hrs.
2	15-Feb-19	0:00:00	15-Feb-19	0:00:00	0:00:00	0.00	0.000	
3	15-Feb-19	0:00:00	15-Feb-19	12:25:00	12:25:00	33.00	0.359	
4	15-Feb-19	0:00:00	15-Feb-19	24:00:00	24:00:00	34.00	0.757	
5	15-Feb-19	00:00 10:55	15-Feb-19	6:00 24:00	19:05:00	32.00	0.589	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	15-Feb-19	0:00:00	15-Feb-19	0:00:00	0:00:00	0	0.000	Today(i.e. 16.02.2019), no SSP-RBPH M/c is scheduled
2	15-Feb-19	0:00:00	15-Feb-19	0:00:00	0:00:00	0	0.000	
3	15-Feb-19	0:00:00	15-Feb-19	0:00:00	0:00:00	0	0.000	
4	15-Feb-19	0:00:00	15-Feb-19	0:00:00	0:00:00	0	0.000	
5	15-Feb-19	0:00:00	15-Feb-19	0:00:00	0:00:00	0	0.000	
6	15-Feb-19	0:00:00	15-Feb-19	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	1.893	0.000	1.893
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	35.316	0.000	35.316
PREVIOUS DAY ACTUAL RUNNING HOURS	62:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 16-Feb-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 117.87 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 5227 Cusec 13 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 13082 Cusec 32 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
11572	608

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
608	0	12575	13082	0	311



for
16/02/19

AEÉ (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP-Asoj, Kasor, Raj-1 and Dhule-2 lines are in service.

2. SSP SCO Running Details:

Unit No.2: 20:20 hrs on 15.02.19 to 06:45 hrs on 16.02.19.

Unit No.5: 20:25 hrs on 15.02.19 to 06:50 hrs on 16.02.19.