



**DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES**  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 17-Feb-19  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 16-Feb-19

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	16-Feb-19	0:00:00	16-Feb-19	12:50:00	12:50:00	31.00	0.383	Today(i.e. 17.02.2019), 3 CHPH M/cs are running at 10:00 hrs.
2	16-Feb-19	0:00:00	16-Feb-19	0:00:00	0:00:00	0.00	0.000	
3	16-Feb-19	11:45:00	16-Feb-19	24:00:00	12:15:00	32.00	0.370	
4	16-Feb-19	0:00:00	16-Feb-19	24:00:00	24:00:00	33.00	0.744	
5	16-Feb-19	0:00:00	16-Feb-19	24:00:00	24:00:00	31.00	0.716	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	16-Feb-19	0:00:00	16-Feb-19	0:00:00	0:00:00	0	0.000	Today(i.e. 17.02.2019), no SSP-RBPH M/c is scheduled
2	16-Feb-19	0:00:00	16-Feb-19	0:00:00	0:00:00	0	0.000	
3	16-Feb-19	0:00:00	16-Feb-19	0:00:00	0:00:00	0	0.000	
4	16-Feb-19	0:00:00	16-Feb-19	0:00:00	0:00:00	0	0.000	
5	16-Feb-19	0:00:00	16-Feb-19	0:00:00	0:00:00	0	0.000	
6	16-Feb-19	0:00:00	16-Feb-19	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	2.213	0.000	2.213
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	37.529	0.000	37.529
PREVIOUS DAY ACTUAL RUNNING HOURS	73:05:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 17-Feb-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 117.66 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 3108 Cusec 8 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 15050 Cusec 37 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
12574	608

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
600	0	14548	15050	0	309



for Archita Karange  
17.2.19  
AEE (EMC)  
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP-Asoj, Kasor, Raj-1 and Dhule-2 lines are in service.

2. SSP SCO Running Details:

Unit No.2: 21:40 hrs on 16.02.19 to 07:10 hrs on 17.02.19.

Unit No.6: 21:50 hrs on 16.02.19 to 07:15 hrs on 17.02.19.