



(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN Mus	REMARKS
1	17-Feb-19	0:00:00	17-Feb-19	0:00:00	0:00:00	0.00	0.000	Today(i.e. 18.02.2019), 3 CHPH M/cs are running at 10:00 hrs.
2	17-Feb-19	0:00:00	17-Feb-19	0:00:00	0:00:00	0.00	0.000	
3	17-Feb-19	0:00:17:00	17-Feb-19	16:42:24:00	23:42:00	32.00	0.709	
4	17-Feb-19	0:00:00	17-Feb-19	24:00:00	24:00:00	32.00	0.742	
5	17-Feb-19	0:00:00	17-Feb-19	24:00:00	24:00:00	31.00	0.729	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN Mus	REMARKS
1	17-Feb-19	0:00:00	17-Feb-19	0:00:00	0:00:00	0	0.000	Today(i.e. 18.02.2019), no SSP-RBPH M/c is scheduled
2	17-Feb-19	0:00:00	17-Feb-19	0:00:00	0:00:00	0	0.000	
3	17-Feb-19	0:00:00	17-Feb-19	0:00:00	0:00:00	0	0.000	
4	17-Feb-19	0:00:00	17-Feb-19	0:00:00	0:00:00	0	0.000	
5	17-Feb-19	0:00:00	17-Feb-19	0:00:00	0:00:00	0	0.000	
6	17-Feb-19	0:00:00	17-Feb-19	0:00:00	0:00:00	0	0.000	

					CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)					2.180	0.000	2.180
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)					39.709	0.000	39.709
PREVIOUS DAY ACTUAL RUNNING HOURS					71:42:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)					72:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)					72:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 18-Feb-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 117.42 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 1907 Cusec 5 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 15612 Cusec 38 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
14545	600

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
610	0	14692	15612	0	307



जल सार्वजनिक - जल सेवा

Handwritten signature and date: 18/2/19
AEE (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member(Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG. CE(E&M), SSNNL, Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP-Asoj, Kasor, Raj.-1, Dhule-1 and Dhule-2 lines are in service.

2. SSP SCO Running Details:

Unit No.6: 18:20 hrs on 17.02.19 to 07:05hrs on 18.02.19.

Unit No.1: 18:25 hrs on 17.02.19 to 05:20 hrs on 18.02.19.

Unit No.2: 22:15 hrs on 17.02.19 to 05:25 hrs on 18.02.19.