



(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	18-Feb-19	5:00:00	18-Feb-19	24:00:00	19:00:00	30.00	0.543	Today(i.e. 19.02.2019), 3 CHPH M/cs are running at 10:00 hrs. SSP-CHPH Unit no.4 under AOH work from 18.02.2019.
2	18-Feb-19	0:00:00	18-Feb-19	0:00:00	0:00:00	0.00	0.000	
3	18-Feb-19	0:00:00	18-Feb-19	24:00:00	24:00:00	32.00	0.719	
4	18-Feb-19	0:00:00	18-Feb-19	7:30:00	7:30:00	31.00	0.229	
5	18-Feb-19	0:00:00	18-Feb-19	24:00:00	24:00:00	30.00	0.719	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	18-Feb-19	0:00:00	18-Feb-19	0:00:00	0:00:00	0	0.000	Today(i.e. 19.02.2019), no SSP-RBPH M/c is scheduled. SSP-RBPH Unit no.4 under AOH work from 15.02.2019.
2	18-Feb-19	0:00:00	18-Feb-19	0:00:00	0:00:00	0	0.000	
3	18-Feb-19	0:00:00	18-Feb-19	0:00:00	0:00:00	0	0.000	
4	18-Feb-19	0:00:00	18-Feb-19	0:00:00	0:00:00	0	0.000	
5	18-Feb-19	0:00:00	18-Feb-19	0:00:00	0:00:00	0	0.000	
6	18-Feb-19	0:00:00	18-Feb-19	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	2.210	0.000	2.210
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	41.919	0.000	41.919
PREVIOUS DAY ACTUAL RUNNING HOURS	74:30:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	66:30:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 19-Feb-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 117.20 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 1307 Cusec 3 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 13854 Cusec 34 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
14525	610

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
608	0	13834	13854	0	304



Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.
1. 400 kV SSP-Asoj, Kasor, Raj.-1, and Dhule-1 lines are in service.

2. SSP SCO Running Details:

Unit No.6: 18:10 hrs on 18.02.19 to 05:45 hrs on 19.02.19.

Unit No.2: 18:20 hrs on 18.02.19 to 05:40 hrs on 19.02.19.

AEE (EMC)
NCA, INDORE

Touseef Ali
JE (EMC)
19/02