



DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 20-Feb-19  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 19-Feb-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	19-Feb-19	0:00 1:00	19-Feb-19	6:30 24:00	18:30:00	30.00	0.548	Today(i.e. 20.02.2019), 4 CHPH M/cs are running at 10:00 hrs. SSP-CHPH Unit no.4 is under AOH work from 18.02.2019.
2	19-Feb-19	0:00:00	19-Feb-19	0:00:00	0:00:00	0.00	0.000	
3	19-Feb-19	0:00:00	19-Feb-19	24:00:00	24:00:00	32.00	0.713	
4	19-Feb-19	0:00:00	19-Feb-19	0:00:00	0:00:00	0.00	0.000	
5	19-Feb-19	0:00:00	19-Feb-19	24:00:00	24:00:00	31.00	0.723	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	19-Feb-19	0:00:00	19-Feb-19	0:00:00	0:00:00	0	0.000	Today(i.e. 20.02.2019), no SSP-RBPH M/c is scheduled. SSP-RBPH Unit no.4 under AOH work from 15.02.2019.
2	19-Feb-19	0:00:00	19-Feb-19	0:00:00	0:00:00	0	0.000	
3	19-Feb-19	0:00:00	19-Feb-19	0:00:00	0:00:00	0	0.000	
4	19-Feb-19	0:00:00	19-Feb-19	0:00:00	0:00:00	0	0.000	
5	19-Feb-19	0:00:00	19-Feb-19	0:00:00	0:00:00	0	0.000	
6	19-Feb-19	0:00:00	19-Feb-19	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	1.984	0.000	1.984
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	43.903	0.000	43.903
PREVIOUS DAY ACTUAL RUNNING HOURS	66:30:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 20-Feb-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 116.96 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 1095 Cusec 3 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 14805 Cusec 36 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
13834	608

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
635	0	14081	14805	0	302



*[Signature]*  
AEE (EMC)  
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP-Asoj, Kasor, Raj.-1,Raj-2 and Dhule-1 lines are in service.

2. SSP SCO Running Details:

Unit No.6: 20:30 hrs on 19.02.19 to 06:35 hrs on 20.02.19.

Unit No.2: 20:40 hrs on 19.02.19 to 06:30 hrs on 20.02.19.