



DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 01-Feb-20  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 31-Jan-20

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	31-Jan-20	0:00:00	31-Jan-20	24:00:00	24:00:00	15.00	0.354	Today(i.e. 01.02.2020), 5 SSP-CHPH M/cs are running at 10:00 hrs.
2	31-Jan-20	0:00:00	31-Jan-20	24:00:00	24:00:00	15.00	0.354	
3	31-Jan-20	0:00:00	31-Jan-20	24:00:00	24:00:00	51.00	1.179	
4	31-Jan-20	0:00:00	31-Jan-20	24:00:00	24:00:00	52.00	1.223	
5	31-Jan-20	0:00:00	31-Jan-20	24:00:00	24:00:00	51.00	1.194	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	31-Jan-20	07:00 14:15	31-Jan-20	11:15 18:30	8:30:00	202	1.708	Today(i.e. 01.02.2020), 5 SSP-RBPH M/cs are running at 10:00 hrs.  RBPH Unit No. 3 is under AOH from 17.01.2020 to 06.02.2020
2	31-Jan-20	6:45 14:30	31-Jan-20	11:30 18:45	9:00:00	203	1.812	
3	31-Jan-20	0:00:00	31-Jan-20	0:00:00	0:00:00	0	0.000	
4	31-Jan-20	6:15:00	31-Jan-20	11:45:00	5:30:00	201	1.112	
5	31-Jan-20	6:00:00	31-Jan-20	12:00:00	6:00:00	202	1.222	
6	31-Jan-20	7:15:00	31-Jan-20	19:00:00	11:45:00	204	2.376	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	4.304	8.230	12.534
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	121.321	231.334	352.655
PREVIOUS DAY ACTUAL RUNNING HOURS	120:00:00	40:45:00	
TODAY'S DC (Schedule) Planned (in Hours)	120:00:00	40:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	120:00:00	40:15:00	

SSP hydrological data : at 08:00 Hrs on 1-Feb-20

**DATA RECEIVED FROM FLOOD CELL**

- RESERVOIR LEVEL IN Metres 129.59 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 18779 Cusec 46 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 30514 Cusec 75 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
19541	477

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
458	0	19599	18878	11636	450



जल बचत - जल संयोजन

Archita Kaniing  
J. E. (Elect.)  
EMC/NCA

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Running Detail:

Unit No.5: 20:20hrs on 31.01.2020 to 05:00 hrs on 01.02.2020.

Unit No.6: 00:20hrs on 01.02.2020 to 05:25 hrs on 01.02.2020.

Unit No.4: 00:30hrs on 01.02.2020 to 05:20 hrs on 01.02.2020.

AEE (EMC)  
NCA, INDORE