



DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 10-Feb-20  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 09-Feb-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	9-Feb-20	0:00:00	9-Feb-20	0:00:00	0:00:00	0.00	0.000	Today(i.e. 10.02.2020), 4 SSP-CHPH M/cs are running at 10:00 hrs.
2	9-Feb-20	9:00:00	9-Feb-20	24:00:00	15:00:00	15.00	0.218	
3	9-Feb-20	0:00:00	9-Feb-20	24:00:00	24:00:00	50.00	1.185	
4	9-Feb-20	0:00:00	9-Feb-20	24:00:00	24:00:00	51.00	1.206	
5	9-Feb-20	0:00:00	9-Feb-20	24:00:00	24:00:00	52.00	1.205	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	9-Feb-20	6:00 14:45	9-Feb-20	11:30 18:00	8:45:00	204	1.770	Today(i.e. 10.02.2020), 5 SSP-RBPH M/cs are running at 10:00 hrs.
2	9-Feb-20	0:00:00	9-Feb-20	0:00:00	0:00:00	0	0.000	
3	9-Feb-20	6:15:00	9-Feb-20	11:45:00	5:30:00	202	1.104	
4	9-Feb-20	06:30 15:00	9-Feb-20	12:00 18:15	8:45:00	203	1.780	
5	9-Feb-20	6:45:00	9-Feb-20	18:30:00	11:45:00	203	2.392	
6	9-Feb-20	7:00 15:15	9-Feb-20	12:15 18:45	8:45:00	204	1.776	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	3.814	8.822	12.636
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	35.614	76.642	112.256
PREVIOUS DAY ACTUAL RUNNING HOURS	87:00:00	43:30:00	
TODAY'S DC (Schedule) Planned (in Hours)	96:00:00	41:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	41:00:00	

SSP hydrological data : at 08:00 Hrs on 10-Feb-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 127.97 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 11170 Cusec 27 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 30378 Cusec 74 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
16498	412

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
473	0	17803	18127	12251	477



AEE (EMC)  
NCA, INDORE

10/2/2020

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Running Detail:

Unit No.2: 20:05 hrs on 09.02.2020 to 05:10 hrs on 10.02.2020.

Unit No.5: 21:25 hrs on 09.02.2020 to 05:15 hrs on 10.02.2020.

Unit No.6: 21:40 hrs on 09.02.2020 to 6:35 hrs on 10.02.2020.