



DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 11-Feb-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 10-Feb-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	10-Feb-20	0:00:00	10-Feb-20	0:00:00	0:00:00	0.00	0.000	Today(i.e. 11.02.2020), 4 SSP-CHPH M/cs are running at 10:00 hrs.
2	10-Feb-20	0:00:00	10-Feb-20	24:00:00	24:00:00	15.00	0.354	
3	10-Feb-20	0:00:00	10-Feb-20	24:00:00	24:00:00	50.00	1.193	
4	10-Feb-20	0:00:00	10-Feb-20	24:00:00	24:00:00	52.00	1.198	
5	10-Feb-20	0:00:00	10-Feb-20	24:00:00	24:00:00	51.00	1.198	

(RBPB 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	10-Feb-20	6:15:00	10-Feb-20	11:30:00	5:15:00	202	1.048	Today(i.e. 11.02.2020), 5 SSP-RBPB M/cs are running at 10:00 hrs. RBPB Unit No. 4 is under AOH from 11.02.2020 to 02.03.2020
2	10-Feb-20	14:45:00	10-Feb-20	18:45:00	4:00:00	204	0.804	
3	10-Feb-20	06:30 15:15	10-Feb-20	11:45 18:15	8:15:00	203	1.660	
4	10-Feb-20	06:45 15:30	10-Feb-20	12:00 18:00	7:45:00	203	1.570	
5	10-Feb-20	7:15:00	10-Feb-20	17:45:00	10:30:00	204	2.130	
6	10-Feb-20	7:10:00	10-Feb-20	12:25:00	5:15:00	203	1.054	

	CHPH (5 X 50MW)	RBPB (6X200 MW)	SSP(CHPH+RBPB)
GROSS GENERATION IN(MUs)	3.943	8.266	12.209
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	39.557	84.908	124.465
PREVIOUS DAY ACTUAL RUNNING HOURS	96:00:00	41:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	96:00:00	41:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	42:15:00	

SSP hydrological data : at 08:00 Hrs on 11-Feb-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 127.73 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 8304 Cusec 20 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 30329 Cusec 74 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
17803	473

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPB	Ev. Loss
0	0	18048	18204	12125	472



(Signature)
11/2/2020
AEE (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Running Detail:

Unit No.1: 20:20 hrs on 10.02.2020 to 05:45 hrs on 11.02.2020.