



DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 12-Feb-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 11-Feb-20

(CHPH 5X50 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUS | REMARKS |
|----------|-----------|---------|-----------|----------|-------------|----------------|-------------------|-------------------------------------------------------------------|
| 1 | 11-Feb-20 | 0:00:00 | 11-Feb-20 | 0:00:00 | 0:00:00 | 0.00 | 0.000 | Today(i.e. 12.02.2020), 4 SSP-CHPH M/cs are running at 10:00 hrs. |
| 2 | 11-Feb-20 | 0:00:00 | 11-Feb-20 | 24:00:00 | 24:00:00 | 15.00 | 0.349 | |
| 3 | 11-Feb-20 | 0:00:00 | 11-Feb-20 | 24:00:00 | 24:00:00 | 50.00 | 1.181 | |
| 4 | 11-Feb-20 | 0:00:00 | 11-Feb-20 | 24:00:00 | 24:00:00 | 51.00 | 1.207 | |
| 5 | 11-Feb-20 | 0:00:00 | 11-Feb-20 | 24:00:00 | 24:00:00 | 52.00 | 1.197 | |

(RBPH 6X200 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUS | REMARKS |
|----------|-----------|----------------|-----------|----------------|-------------|----------------|-------------------|-------------------------------------------------------------------------------------------------------------------------------------|
| 1 | 11-Feb-20 | 7:15:00 | 11-Feb-20 | 11:30:00 | 4:15:00 | 202 | 0.862 | Today(i.e. 12.02.2020), 5 SSP-RBPH M/cs are running at 10:00 hrs. RBPH Unit No. 4 is under AOH from 11.02.2020 to 02.03.2020 |
| 2 | 11-Feb-20 | 7:00 14:45 | 11-Feb-20 | 11:45 18:45 | 8:45:00 | 203 | 1.772 | |
| 3 | 11-Feb-20 | 06:45 15:30 | 11-Feb-20 | 12:15 18:15 | 8:15:00 | 203 | 1.668 | |
| 4 | 11-Feb-20 | 0:00:00 | 11-Feb-20 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 5 | 11-Feb-20 | 06:30 15:15 | 11-Feb-20 | 12:00 18:00 | 8:15:00 | 202 | 1.666 | |
| 6 | 11-Feb-20 | 6:15:00 | 11-Feb-20 | 17:45:00 | 11:30:00 | 203 | 2.326 | |

| | CHPH (5 X 50MW) | RBPH (6X200 MW) | SSP(CHPH+RBPH) |
|------------------------------------------|-----------------|-----------------|----------------|
| GROSS GENERATION IN(MUS) | 3.934 | 8.294 | 12.228 |
| CUMMULATIVE GROSS GEN. FOR MONTH (MUS) | 43.491 | 93.202 | 136.693 |
| PREVIOUS DAY ACTUAL RUNNING HOURS | 96:00:00 | 41:00:00 | |
| TODAY'S DC (Schedule) Planned (in Hours) | 96:00:00 | 40:45:00 | |
| DAY AHEAD (TOMMORROW) DC (in Hours) | 96:00:00 | 42:45:00 | |

SSP hydrological data : at 08:00 Hrs on 12-Feb-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 127.48 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 7252 Cusec 18 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 30219 Cusec 74 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

| HR | GODBOLE |
|-------|---------|
| 18048 | 0 |

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

| GODBOLE | OVER FLOW | HR | CHPH | RBPH | Ev. Loss |
|---------|-----------|-------|-------|-------|----------|
| 446 | 0 | 18522 | 18331 | 11888 | 467 |



[Signature]
AEE (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Running Detail:

Unit No.6: 20:20 hrs on 11.02.2020 to 05:45 hrs on 12.02.2020.

Unit No.5: 20:30 hrs on 11.02.2020 to 05:50 hrs on 12.02.2020.