



**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	16-Feb-20	0:00:00	16-Feb-20	6:30:00	6:30:00	15.00	0.092	Today(i.e. 17.02.2020), 3 SSP-CHPH M/cs are running at 10:00 hrs.
2	16-Feb-20	0:00:00	16-Feb-20	0:00:00	0:00:00	0.00	0.000	
3	16-Feb-20	0:00:00	16-Feb-20	24:00:00	24:00:00	50.00	1.142	
4	16-Feb-20	0:00:00	16-Feb-20	24:00:00	24:00:00	51.00	1.158	
5	16-Feb-20	0:00:00	16-Feb-20	24:00:00	24:00:00	49.00	1.131	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	16-Feb-20	0:00:00	16-Feb-20	0:00:00	0:00:00	0	0.000	Today(i.e. 17.02.2020), 3 SSP-RBPH M/cs are running at 10:00 hrs. RBPH Unit No. 4 is under AOH from 11.02.2020 to 02.03.2020
2	16-Feb-20	5:15:00	16-Feb-20	18:15:00	13:00:00	203	2.618	
3	16-Feb-20	5:30:00	16-Feb-20	19:15:00	13:45:00	203	2.768	
4	16-Feb-20	0:00:00	16-Feb-20	0:00:00	0:00:00	0	0.000	
5	16-Feb-20	0:00:00	16-Feb-20	0:00:00	0:00:00	0	0.000	
6	16-Feb-20	6:30:00	16-Feb-20	19:30:00	13:00:00	203	2.628	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	3.523	8.014	11.537
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	62.518	132.316	194.834
PREVIOUS DAY ACTUAL RUNNING HOURS	78:30:00	39:45:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	39:45:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	41:15:00	

SSP hydrological data : at 08:00 Hrs on 17-Feb-20

**DATA RECEIVED FROM FLOOD CELL.**

- RESERVOIR LEVEL IN Metres 126.21 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 6079 Cusec 15 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 27197 Cusec 67 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
17804	576

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
575	0	17708	16307	10890	441



जल बचत - जल संयम

For Archita Kamnaga  
J.E. (Elect.)  
EMC, NCA

AEE (EMC)  
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member(Power), NVDA, Bhopal

GoMah. CE, WRD, Mumbai

GoG CE(E&M), SSNNL, Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Raj-1 and Raj-2 lines are in service.

2. Dhule-I, II Out due to tower collapsed.

3. SCO Mode Running Detail:

Unit No.5: 20:10 hrs on 16.02.2020 to 05:40 hrs on 17.02.2020.

Unit No.2: 21:40 hrs on 16.02.2020 to 04:15 hrs on 17.02.2020.

Unit No.6: 21:45 hrs on 16.02.2020 to 04:20 hrs on 17.02.2020.