



(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	17-Feb-20	17:15:00	17-Feb-20	24:00:00	6:45:00	15.00	0.095	Today(i.e. 18.02.2020), 4 SSP-CHPH M/cs are running at 10:00 hrs.
2	17-Feb-20	0:00:00	17-Feb-20	0:00:00	0:00:00	0.00	0.000	
3	17-Feb-20	0:00:00	17-Feb-20	24:00:00	24:00:00	49.00	1.149	
4	17-Feb-20	0:00:00	17-Feb-20	24:00:00	24:00:00	49.00	1.157	
5	17-Feb-20	0:00:00	17-Feb-20	24:00:00	24:00:00	48.00	1.136	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	17-Feb-20	0:00:00	17-Feb-20	0:00:00	0:00:00	0	0.000	Today(i.e. 18.02.2020), 3 SSP-RBPH M/cs are running at 10:00 hrs. RBPH Unit No. 4 is under AOH from 11.02.2020 to 02.03.2020
2	17-Feb-20	6:05:00	17-Feb-20	19:20:00	13:15:00	203	2.668	
3	17-Feb-20	6:30:00	17-Feb-20	19:30:00	13:00:00	202	2.612	
4	17-Feb-20	0:00:00	17-Feb-20	0:00:00	0:00:00	0	0.000	
5	17-Feb-20	0:00:00	17-Feb-20	0:00:00	0:00:00	0	0.000	
6	17-Feb-20	6:15:00	17-Feb-20	19:45:00	13:30:00	202	2.728	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	3.537	8.008	11.545
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	66.055	140.324	206.379
PREVIOUS DAY ACTUAL RUNNING HOURS	78:45:00	39:45:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	40:30:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	40:00:00	

SSP hydrological data : at 08:00 Hrs on 18-Feb-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 125.99 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 9870 Cusec 24 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 29859 Cusec 73 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
17726	575

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	18035	17907	11952	437



for Shubh 17/2/20
JE, EMC, NCA

AEE (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member(Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG CE(E&M), SSNNL, Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Raj-1 and Raj-2 lines are in service.

2. Dhule-I, II Out due to tower collapsed.

3. SCO Mode Running Detail:

Unit No.5: 21:25 hrs on 17.02.2020 to 04:15 hrs on 18.02.2020.

Unit No.6: 21:30 hrs on 17.02.2020 to 04:20 hrs on 18.02.2020.