



DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 20-Feb-20  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 19-Feb-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	19-Feb-20	0:00 15:00	19-Feb-20	14:35 24:00	23:35:00	15.00	0.333	Today(i.e. 20.02.2020), 4 SSP-CHPH M/cs are running at 10:00 hrs.
2	19-Feb-20	0:00:00	19-Feb-20	0:00:00	0:00:00	0.00	0.000	
3	19-Feb-20	0:00:00	19-Feb-20	24:00:00	24:00:00	47.00	1.125	
4	19-Feb-20	0:00:00	19-Feb-20	24:00:00	24:00:00	48.00	1.142	
5	19-Feb-20	0:00:00	19-Feb-20	24:00:00	24:00:00	48.00	1.121	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	19-Feb-20	6:45:00	19-Feb-20	12:00:00	5:15:00	203	1.060	Today(i.e. 20.02.2020), 4 SSP-RBPH M/cs are running at 10:00 hrs.  RBPH Unit No. 4 is under AOH from 11.02.2020 to 02.03.2020
2	19-Feb-20	6:00:00	19-Feb-20	18:30:00	12:30:00	205	2.518	
3	19-Feb-20	14:30:00	19-Feb-20	18:45:00	4:15:00	203	0.860	
4	19-Feb-20	0:00:00	19-Feb-20	0:00:00	0:00:00	0	0.000	
5	19-Feb-20	6:15:00	19-Feb-20	11:45:00	5:30:00	201	1.116	
6	19-Feb-20	6:30:00	19-Feb-20	19:00:00	12:30:00	203	2.534	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	3.721	8.088	11.809
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	73.514	156.552	230.066
PREVIOUS DAY ACTUAL RUNNING HOURS	95:35:00	40:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	40:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	40:15:00	

SSP hydrological data : at 08:00 Hrs on 20-Feb-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 125.44 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 9319 Cusec 23 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 30366 Cusec 74 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
18699	475

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
444	0	18685	18388	11978	428



Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 KV SSP Asoj, Kasor, Raj-1 and Raj-2 lines are in service.

2. Dhule-I, II Out due to tower collapse.

3. SCO Mode Running Detail:

Unit No.5: 20:40 hrs on 19.02.2020 to 05:40 hrs on 20.02.2020.

*for*  
AEE (EMC)  
NCA, INDORE