



(CHPH 5X50 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUs | REMARKS |
|----------|-----------|---------|-----------|----------|-------------|----------------|-------------------|---|
| 1 | 24-Feb-20 | 0:00:00 | 24-Feb-20 | 24:00:00 | 24:00:00 | 14.00 | 0.321 | Today(i.e. 26.02.2020), 5 SSP-CHPH M/cs are running at 10:00 hrs. |
| 2 | 24-Feb-20 | 8:00:00 | 24-Feb-20 | 24:00:00 | 16:00:00 | 13.00 | 0.204 | |
| 3 | 24-Feb-20 | 0:00:00 | 24-Feb-20 | 24:00:00 | 24:00:00 | 45.00 | 1.045 | |
| 4 | 24-Feb-20 | 0:00:00 | 24-Feb-20 | 24:00:00 | 24:00:00 | 46.00 | 1.088 | |
| 5 | 24-Feb-20 | 0:00:00 | 24-Feb-20 | 24:00:00 | 24:00:00 | 45.00 | 1.066 | |

(RBPH 6X200 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUs | REMARKS |
|----------|-----------|-------------------|-----------|----------------|-------------|----------------|-------------------|---|
| 1 | 24-Feb-20 | 6:15 15:00 | 24-Feb-20 | 11:30 18:15 | 8:30:00 | 203 | 1.710 | Today(i.e. 26.02.2020), 5 SSP-RBPH M/cs are running at 10:00 hrs. RBPH Unit No. 4 is under AOH from 11.02.2020 to 02.03.2020 |
| 2 | 24-Feb-20 | 06:30:00 15:15 | 24-Feb-20 | 11:45 18:30 | 8:30:00 | 201 | 1.716 | |
| 3 | 24-Feb-20 | 6:45:00 | 24-Feb-20 | 12:00:00 | 5:15:00 | 202 | 1.058 | |
| 4 | 24-Feb-20 | 0:00:00 | 24-Feb-20 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 5 | 24-Feb-20 | 7:00:00 | 24-Feb-20 | 18:00:00 | 11:00:00 | 202 | 2.220 | |
| 6 | 24-Feb-20 | 15:30:00 | 24-Feb-20 | 18:45:00 | 3:15:00 | 203 | 0.666 | |

| | CHPH (5 X 50MW) | RBPH (6X200 MW) | SSP(CHPH+RBPH) |
|--|-----------------|-----------------|----------------|
| GROSS GENERATION IN(MUs) | 3.724 | 7.370 | 11.094 |
| CUMMULATIVE GROSS GEN. FOR MONTH (MUs) | 95.513 | 204.738 | 300.251 |
| PREVIOUS DAY ACTUAL RUNNING HOURS | 112:00:00 | 36:30:00 | |
| TODAY'S DC (Schedule) Planned (in Hours) | 120:00:00 | 35:15:00 | |
| DAY AHEAD (TOMMORROW) DC (in Hours) | 120:00:00 | 36:15:00 | |

SSP hydrological data : at 08:00 Hrs on 26-Feb-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 124.12 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 4878 Cusec 12 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 30390 Cusec 74 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

| HR | GODBOLE |
|-------|---------|
| 18825 | 0 |

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

| GODBOLE | OVER FLOW | HR | CHPH | RBPH | Ev. Loss |
|---------|-----------|-------|-------|-------|----------|
| 675 | 0 | 18953 | 19803 | 10587 | 406 |



जल संचयन - जल संयम

(Signature)
AEE (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-I, Dhule-II, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Running Detail:

Unit No.5: 21:55 hrs on 26.02.2020 to 05:10 hrs on 27.02.2020.

Unit No.6: 22:05 hrs on 26.02.2020 to 05:15 hrs on 27.02.2020.