



(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	27-Feb-20	0:00:00	27-Feb-20	24:00:00	24:00:00	13.00	0.307	Today(i.e. 28.02.2020), 5 SSP-CHPH M/cs are running at 10:00 hrs.
2	27-Feb-20	5:00:00	27-Feb-20	24:00:00	19:00:00	13.00	0.237	
3	27-Feb-20	0:00:00	27-Feb-20	24:00:00	24:00:00	43.00	1.007	
4	27-Feb-20	0:00:00	27-Feb-20	24:00:00	24:00:00	45.00	1.038	
5	27-Feb-20	0:00:00	27-Feb-20	24:00:00	24:00:00	44.00	1.016	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	27-Feb-20	6:15:00	27-Feb-20	10:45:00	4:30:00	200	0.896	Today(i.e. 28.02.2020), 4 SSP-RBPH M/cs are running at 10:00 hrs. RBPH Unit No. 4 is under AOH from 11.02.2020 to 02.03.2020
2	27-Feb-20	6:30:00	27-Feb-20	11:30:00	5:00:00	201	0.996	
3	27-Feb-20	6:45:00	27-Feb-20	10:15:00	3:30:00	199	0.696	
4	27-Feb-20	0:00:00	27-Feb-20	0:00:00	0:00:00	0	0.000	
5	27-Feb-20	7:00:00	27-Feb-20	11:45:00	4:45:00	199	0.946	
6	27-Feb-20	7:15:00	27-Feb-20	18:45:00	11:30:00	201	2.306	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	3.605	5.840	9.445
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	102.754	217.612	320.366
PREVIOUS DAY ACTUAL RUNNING HOURS	115:00:00	29:15:00	
TODAY'S DC (Schedule) Planned (in Hours)	144:00:00	20:15:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	120:00:00	15:00:00	

SSP hydrological data : at 08:00 Hrs on 28-Feb-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 123.66 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 17718 Cusec 43 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 27689 Cusec 68 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
19784	672

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
691	0	19956	19554	8135	396



जल बचत - जल संयोजन

For Shrivastava
28/2/20
JG, EMC, NCA

AEE (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member(Power), NVDA, Bhopal

GoMah. CE, WRD, Mumbai

GoG CE(E&M), SSNNL, Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-I, Dhule-II, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Running Detail:

Unit No.5: 20:15hrs on 27.02.2020 to 05:20 hrs on 28.02.2020.

Unit No.6: 21:35 hrs on 27.02.2020 to 05:25hrs on 28.02.2020.

Unit No3: 21:45 hrs on 27.02.2020 to 05:50hrs on 28.02.2020.