



(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	28-Feb-20	0:00:00	28-Feb-20	24:00:00	24:00:00	13.00	0.298	Today(i.e. 29.02.2020), 5 SSP-CHPH M/cs are running at 10:00 hrs.
2	28-Feb-20	0:00:00	28-Feb-20	24:00:00	24:00:00	14.00	0.301	
3	28-Feb-20	0:00:00	28-Feb-20	24:00:00	24:00:00	43.00	1.006	
4	28-Feb-20	0:00:00	28-Feb-20	24:00:00	24:00:00	44.00	1.024	
5	28-Feb-20	0:00:00	28-Feb-20	24:00:00	24:00:00	43.00	1.012	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	28-Feb-20	6:20:00	28-Feb-20	9:45:00	3:25:00	200	0.674	Today(i.e. 29.02.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs. RBPH Unit No. 4 is under AOH from 11.02.2020 to 02.03.2020
2	28-Feb-20	6:30:00	28-Feb-20	10:45:00	4:15:00	199	0.838	
3	28-Feb-20	8:05:00	28-Feb-20	11:30:00	3:25:00	201	0.680	
4	28-Feb-20	0:00:00	28-Feb-20	0:00:00	0:00:00	0	0.000	
5	28-Feb-20	6:45:00	28-Feb-20	11:00:00	4:15:00	200	0.850	
6	28-Feb-20	8:00:00	28-Feb-20	11:15:00	3:15:00	200	0.646	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	3.641	3.688	7.329
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	106.395	221.300	327.695
PREVIOUS DAY ACTUAL RUNNING HOURS	120:00:00	18:35:00	
TODAY'S DC (Schedule) Planned (in Hours)	96:00:00	15:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	120:00:00	27:00:00	

SSP hydrological data : at 08:00 Hrs on 29-Feb-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 123.92 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 43103 Cusec 105 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 23453 Cusec 57 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
19955	691

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
648	0	19516	19320	4133	397



For Archita Kozurego
J.E. (Elect. Engg.)
EMC, NCA

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member(Power), NVDA, Bhopal

GoMah. CE, WRD, Mumbai

GoG CE(E&M), SSNNL, Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-I, Dhule-II, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Running Detail: NIL

AEE (EMC)
NCA, INDORE