



(CHPH 5X50 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUS | REMARKS |
|----------|----------|---------|----------|----------|-------------|----------------|-------------------|---|
| 1 | 6-Feb-20 | 0:00:00 | 6-Feb-20 | 0:00:00 | 0:00:00 | 15.00 | 0.000 | Today(i.e. 07.02.2020), 3 SSP-CHPH M/cs are running at 10:00 hrs. |
| 2 | 6-Feb-20 | 0:00:00 | 6-Feb-20 | 16:00:00 | 16:00:00 | 15.00 | 0.232 | |
| 3 | 6-Feb-20 | 0:00:00 | 6-Feb-20 | 24:00:00 | 24:00:00 | 51.00 | 1.178 | |
| 4 | 6-Feb-20 | 0:00:00 | 6-Feb-20 | 24:00:00 | 24:00:00 | 51.00 | 1.205 | |
| 5 | 6-Feb-20 | 0:00:00 | 6-Feb-20 | 24:00:00 | 24:00:00 | 50.00 | 1.163 | |

(RBPH 6X200 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUS | REMARKS |
|----------|----------|----------------|----------|----------------|-------------|----------------|-------------------|---|
| 1 | 6-Feb-20 | 15:15:00 | 6-Feb-20 | 18:45:00 | 3:30:00 | 202 | 0.704 | Today(i.e. 07.02.2020), 5 SSP-RBPH M/cs are running at 10:00 hrs. |
| 2 | 6-Feb-20 | 07:15 14:15 | 6-Feb-20 | 11:15 18:30 | 8:15:00 | 203 | 1.664 | |
| 3 | 6-Feb-20 | 6:45:00 | 6-Feb-20 | 18:15:00 | 11:30:00 | 203 | 2.316 | |
| 4 | 6-Feb-20 | 7:00:00 | 6-Feb-20 | 11:30:00 | 4:30:00 | 201 | 0.910 | |
| 5 | 6-Feb-20 | 06:30 15:30 | 6-Feb-20 | 11:45 19:00 | 8:45:00 | 203 | 1.776 | |
| 6 | 6-Feb-20 | 6:15:00 | 6-Feb-20 | 12:00:00 | 5:45:00 | 202 | 1.156 | |

| | CHPH (5 X 50MW) | RBPH (6X200 MW) | SSP(CHPH+RBPH) |
|--|-----------------|-----------------|----------------|
| GROSS GENERATION IN(MUS) | 3.778 | 8.526 | 12.304 |
| CUMMULATIVE GROSS GEN. FOR MONTH (MUS) | 24.630 | 50.040 | 74.670 |
| PREVIOUS DAY ACTUAL RUNNING HOURS | 88:00:00 | 42:15:00 | |
| TODAY'S DC (Schedule) Planned (in Hours) | 120:00:00 | 44:30:00 | |
| DAY AHEAD (TOMMORROW) DC (in Hours) | 120:00:00 | 43:30:00 | |

SSP hydrological data : at 08:00 Hrs on 7-Feb-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 128.65 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 11282 Cusec 28 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 29538 Cusec 72 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

| HR | GODBOLE |
|-------|---------|
| 16684 | 445 |

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

| GODBOLE | OVER FLOW | HR | CHPH | RBPH | Ev. Loss |
|---------|-----------|-------|-------|-------|----------|
| 590 | 0 | 16021 | 16893 | 12645 | 490 |



जल बचल - जल संचय

for Shreechandra
7/2/20
38, NCA

AEE (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Running Detail:

Unit No.5: 20:30hrs on 06.02.2020 to 05:50 hrs on 07.02.2020.

Unit No.6: 20:40hrs on 06.02.2020 to 05:55 hrs on 07.02.2020.