



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 14-Feb-21
ISSUE TIME: 10:00 Hrs
FOR DATE: 13-Feb-21

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	13-Feb-21	0:00:00	13-Feb-21	24:00:00	24:00:00	50.00	1.200	Today (i.e. 14.02.2021), 4 SSP-CHPH M/cs are running at 10:00 hrs.
2	13-Feb-21	0:00:00	13-Feb-21	24:00:00	24:00:00	50.00	1.190	
3	13-Feb-21	0:00:00	13-Feb-21	0:00:00	0:00:00	0.00	0.000	
4	13-Feb-21	0:00:00	13-Feb-21	24:00:00	24:00:00	51.00	1.205	
5	13-Feb-21	0:00:00	13-Feb-21	24:00:00	24:00:00	50.00	1.187	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	13-Feb-21	0:00:00	13-Feb-21	0:00:00	0:00:00	0	0.000	Today (i.e. 14.02.2021), 4 SSP-RBPH M/cs are running at 10:00 hrs. SSP RBPH Unit No. 4 is under A.O.H. from 08.02.2021.
2	13-Feb-21	7:15:00	13-Feb-21	11:15:00	4:00:00	204	0.818	
3	13-Feb-21	7:30:00	13-Feb-21	11:30:00	4:00:00	204	0.814	
4	13-Feb-21	0:00:00	13-Feb-21	0:00:00	0:00:00	0	0.000	
5	13-Feb-21	7:45:00	13-Feb-21	11:45:00	4:00:00	204	0.824	
6	13-Feb-21	8:00:00	13-Feb-21	12:00:00	4:00:00	205	0.820	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	4.782	3.276	8.058
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	60.239	63.214	123.453
PREVIOUS DAY ACTUAL RUNNING HOURS	96:00:00	16:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	96:00:00	16:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	16:00:00	

SSP hydrological data : at 08:00 Hrs on 14-Feb-21

DATA RECEIVED FROM FLOOD CELL.

- RESERVOIR LEVEL IN Metres 132.88 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 9943 Cusec 24.33 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 23293 Cusec 56.99 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
19468	610

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
620	0	19494	18596	4697	589



Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadodra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Details:

Unit No.5: 20:10 Hrs on 13.02.2021 to 07:00 Hrs on 14.02.2021.

Unit No.1: 20:20 Hrs on 13.02.2021 to 06:55 Hrs on 14.02.2021

EE (EMC)
NCA, INDORE

*J.E. (Elect.)
EMC, NCA
14/02/21*