



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 15-Feb-21  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 14-Feb-21

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	14-Feb-21	0:00:00	14-Feb-21	24:00:00	24:00:00	51.00	1.208	Today (i.e. 15.02.2021), 4 SSP-CHPH M/cs are running at 10:00 hrs.
2	14-Feb-21	0:00:00	14-Feb-21	24:00:00	24:00:00	50.00	1.184	
3	14-Feb-21	8:05:00	14-Feb-21	24:00:00	15:55:00	51.00	0.790	
4	14-Feb-21	0:00:00	14-Feb-21	24:00:00	24:00:00	51.00	1.222	
5	14-Feb-21	0:00:00	14-Feb-21	2:00:00	2:00:00	50.00	0.100	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	14-Feb-21	8:00:00	14-Feb-21	12:00:00	4:00:00	205	0.818	Today (i.e. 15.02.2021), 4 SSP-RBPH M/cs are running at 10:00 hrs.  SSP RBPH Unit No. 4 is under A.O.H. from 08.02.2021.
2	14-Feb-21	7:15:00	14-Feb-21	11:15:00	4:00:00	204	0.816	
3	14-Feb-21	0:00:00	14-Feb-21	0:00:00	0:00:00	0	0.000	
4	14-Feb-21	0:00:00	14-Feb-21	0:00:00	0:00:00	0	0.000	
5	14-Feb-21	7:45:00	14-Feb-21	11:45:00	4:00:00	203	0.828	
6	14-Feb-21	7:30:00	14-Feb-21	11:30:00	4:00:00	204	0.822	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	4.504	3.284	7.788
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	64.743	66.498	131.241
PREVIOUS DAY ACTUAL RUNNING HOURS	89:55:00	16:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	89:00:00	16:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	17:30:00	

SSP hydrological data : at 08:00 Hrs on 15-Feb-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 132.78 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 10891 Cusec 26.65 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 22978 Cusec 56.22 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
19419	620

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
613	0	19469	18301	4677	585



Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG. CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.  
1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, & Raj-1 lines are in service.

2. SCO Mode Running Details:

Unit No.5: 18:10 Hrs on 14.02.2021 to 06:40 Hrs on 15.02.2021.

Unit No.6: 18:20 Hrs on 14.02.2021 to 06:45 Hrs on 15.02.2021

EE (EMC)  
NCA, INDORE

*Handwritten signature and date:*  
J.E. (Elect)  
EMC, NCA  
15/02/21