



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 24-Feb-21  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 23-Feb-21

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	23-Feb-21	0:00:00	23-Feb-21	0:00:00	0:00:00	0.00	0.000	Today (i.e. 24.02.2021), 4 SSP-CHPH M/cs are running at 10:00 hrs.
2	23-Feb-21	0:00:00 13:00:00	23-Feb-21	10:30:00 24:00:00	21:30:00	50.00	1.075	
3	23-Feb-21	0:00:00	23-Feb-21	24:00:00	24:00:00	50.00	1.196	
4	23-Feb-21	0:00:00	23-Feb-21	24:00:00	24:00:00	51.00	1.219	
5	23-Feb-21	0:00:00 06:30:00	23-Feb-21	02:00:00 24:00:00	19:30:00	51.00	0.971	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	23-Feb-21	7:15:00	23-Feb-21	11:30:00	4:15:00	204	0.868	Today (i.e. 24.02.2021), 4 SSP-RBPH M/cs are running at 10:00 hrs.
2	23-Feb-21	7:45:00	23-Feb-21	12:00:00	4:15:00	204	0.868	
3	23-Feb-21	8:00:00	23-Feb-21	11:45:00	3:45:00	204	0.766	
4	23-Feb-21	0:00:00	23-Feb-21	0:00:00	0:00:00	0	0.000	SSP RBPH Unit No. 4 is under A.O.H. from 08.02.2021.
5	23-Feb-21	7:30:00	23-Feb-21	12:30:00	5:00:00	201	1.012	
6	23-Feb-21	8:15:00	23-Feb-21	12:15:00	4:00:00	204	0.818	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	4.461	4.332	8.793
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	104.732	102.560	207.292
PREVIOUS DAY ACTUAL RUNNING HOURS	89:00:00	21:15:00	
TODAY'S DC (Schedule) Planned (in Hours)	91:00:00	15:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	18:00:00	

SSP hydrological data : at 08:00 Hrs on 24-Feb-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 131.60 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 8432 Cusec 20.63 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 25691 Cusec 62.85 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
19400	606

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
605	0	18958	18753	6938	550



जन भयते जन सेवते

*[Signature]*  
24/2/21  
EE (EMC)  
NCA, INDORE

Copy to:

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, & Raj-1 lines are in service.

2. SCO Mode Running Details:

Unit No.5: 20:05 Hrs on 23.02.2021 to 05:15 Hrs on 24.02.2021.

Unit No.6: 20:10 Hrs on 23.02.2021 to 05:20 Hrs on 24.02.2021.