



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 25-Feb-21
ISSUE TIME: 10:00 Hrs
FOR DATE: 24-Feb-21

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	24-Feb-21	0:00:00	24-Feb-21	0:00:00	0:00:00	0.00	0.000	Today (i.e. 25.02.2021), 4 SSP-CHPH M/cs are running at 10:00 hrs.
2	24-Feb-21	0:00:00	24-Feb-21	24:00:00	24:00:00	50.00	1.201	
3	24-Feb-21	0:00:00	24-Feb-21	24:00:00	24:00:00	50.00	1.195	
4	24-Feb-21	0:00:00	24-Feb-21	20:30:00	20:30:00	52.00	1.041	
5	24-Feb-21	0:00:00 07:00:00	24-Feb-21	2:00 24:00	19:00:00	51.00	0.941	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	24-Feb-21	7:00:00	24-Feb-21	10:15:00	3:15:00	204	0.664	Today (i.e. 25.02.2021), 3 SSP-RBPH M/cs are running at 10:00 hrs. SSP RBPH Unit No. 4 is under A.O.H. from 08.02.2021.
2	24-Feb-21	7:15:00	24-Feb-21	10:30:00	3:15:00	204	0.672	
3	24-Feb-21	0:00:00	24-Feb-21	0:00:00	0:00:00	0	0.000	
4	24-Feb-21	0:00:00	24-Feb-21	0:00:00	0:00:00	0	0.000	
5	24-Feb-21	6:30:00	24-Feb-21	11:00:00	4:30:00	204	0.922	
6	24-Feb-21	6:45:00	24-Feb-21	10:45:00	4:00:00	205	0.822	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	4.378	3.080	7.458
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	109.110	105.640	214.750
PREVIOUS DAY ACTUAL RUNNING HOURS	87:30:00	15:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	96:00:00	18:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	16:30:00	

SSP hydrological data : at 08:00 Hrs on 25-Feb-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 131.44 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 8366 Cusec 20.47 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 22818 Cusec 55.83 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
18958	605

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
624	0	19366	17968	4850	547



जल शक्ति - जल संरक्षण

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Details:

Unit No.2: 20:10 Hrs on 24.02.2021 to 05:40 Hrs on 25.02.2021.

Unit No.3: 20:20 Hrs on 24.02.2021 to 05:45 Hrs on 25.02.2021.

EE (EMC)
NCA, INDORE

[Signature]
25/2/21