



DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 10-Jan-19  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 09-Jan-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	9-Jan-19	17:00:00	9-Jan-19	23:00:00	6:00:00	38.00	0.226	Today(i.e. 10.01.2019), 3 CHPH M/cs are running at 10:00 hrs.
2	9-Jan-19	0:00:00	9-Jan-19	0:00:00	0:00:00	0.00	0.000	
3	9-Jan-19	0:00:00	9-Jan-19	24:00:00	24:00:00	42.00	0.966	
4	9-Jan-19	0:00:00	9-Jan-19	24:00:00	24:00:00	43.00	0.984	
5	9-Jan-19	0:00:00	9-Jan-19	24:00:00	24:00:00	42.00	0.962	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	9-Jan-19	0:00:00	9-Jan-19	0:00:00	0:00:00	0	0.000	Today(i.e. 10.01.2019), no SSP-RBPH M/c is scheduled. SSP-RBPH Unit no.2 under AOH from 27.12.2018
2	9-Jan-19	0:00:00	9-Jan-19	0:00:00	0:00:00	0	0.000	
3	9-Jan-19	0:00:00	9-Jan-19	0:00:00	0:00:00	0	0.000	
4	9-Jan-19	0:00:00	9-Jan-19	0:00:00	0:00:00	0	0.000	
5	9-Jan-19	0:00:00	9-Jan-19	0:00:00	0:00:00	0	0.000	
6	9-Jan-19	0:00:00	9-Jan-19	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	3.138	0.000	3.138
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	31.156	0.000	31.156
PREVIOUS DAY ACTUAL RUNNING HOURS	78:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 10-Jan-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 122.94 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 9429 Cusec 23 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 17270 Cusec 42 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
16795	623

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
635	0	16235	17270	0	295



*[Signature]*  
AEE (EMC)  
NCA, INDORE  
10/1/19

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP-Asoj, Kasor, Raj-2, Dhule-2 and Dhule-1 lines are in service at 10:00 hrs.

2. SSP SCO Running Details:

Unit No.3: 19:50 hrs on 09.01.19 to 05:20 hrs on 10.01.19.

Unit No.4: 20:00 hrs on 09.01.19 to 05:25 hrs on 10.01.19.

Unit No.5: 20:20 hrs on 09.01.19 to 06:00 hrs on 10.01.19.