



DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 12-Jan-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 11-Jan-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	11-Jan-19	0:00:00	11-Jan-19	0:00:00	0:00:00	0.00	0.000	Today(i.e. 12.01.2019), 3 CHPH M/cs are running at 10:00 hrs.
2	11-Jan-19	16:30:00	11-Jan-19	22:00:00	5:30:00	41.00	0.214	
3	11-Jan-19	0:00:00	11-Jan-19	24:00:00	24:00:00	42.00	0.958	
4	11-Jan-19	0:00:00	11-Jan-19	24:00:00	24:00:00	42.00	0.988	
5	11-Jan-19	0:00:00	11-Jan-19	24:00:00	24:00:00	42.00	0.959	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	11-Jan-19	0:00:00	11-Jan-19	0:00:00	0:00:00	0	0.000	Today(i.e. 12.01.2019), no SSP-RBPH M/c is scheduled. SSP-RBPH Unit no.2 under AOH from 27.12.2018
2	11-Jan-19	0:00:00	11-Jan-19	0:00:00	0:00:00	0	0.000	
3	11-Jan-19	0:00:00	11-Jan-19	0:00:00	0:00:00	0	0.000	
4	11-Jan-19	0:00:00	11-Jan-19	0:00:00	0:00:00	0	0.000	
5	11-Jan-19	0:00:00	11-Jan-19	0:00:00	0:00:00	0	0.000	
6	11-Jan-19	0:00:00	11-Jan-19	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	3.119	0.000	3.119
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	37.174	0.000	37.174
PREVIOUS DAY ACTUAL RUNNING HOURS	77:30:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 12-Jan-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 122.89 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 12325 Cusec 30 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 17214 Cusec 42 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
15394	635

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
644	0	16216	17214	0	294



for
12/1/19

AEE (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP-Asoj, Kasor, Raj-1, Dhule-2 and Dhule-1 lines are in service at 10:00 hrs.

2. SSP SCO Running Details:

Unit No.5: 19:20hrs on 11.01.19 to 06:25 hrs on 12.01.19.

Unit No.3: 19:25 hrs on 11.01.19 to 06:30 hrs on 12.01.19.