



DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 02-Jan-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 01-Jan-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	1-Jan-19	0:00:00	1-Jan-19	0:00:00	0:00:00	0.00	0.000	Today(i.e. 02.01.2019), 4 CHPH M/cs are running at 10:00 hrs.
2	1-Jan-19	10:00:00	1-Jan-19	24:00:00	14:00:00	40.00	0.539	
3	1-Jan-19	0:00:00	1-Jan-19	24:00:00	24:00:00	43.00	0.981	
4	1-Jan-19	0:00:00	1-Jan-19	24:00:00	24:00:00	44.00	1.019	
5	1-Jan-19	0:00:00	1-Jan-19	24:00:00	24:00:00	42.00	0.981	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	1-Jan-19	0:00:00	1-Jan-19	0:00:00	0:00:00	0	0.000	Today(i.e. 02.01.2019), no SSP-RBPH M/c is scheduled. SSP-RBPH Unit no.2 under AOH from 27.12.2018
2	1-Jan-19	0:00:00	1-Jan-19	0:00:00	0:00:00	0	0.000	
3	1-Jan-19	0:00:00	1-Jan-19	0:00:00	0:00:00	0	0.000	
4	1-Jan-19	0:00:00	1-Jan-19	0:00:00	0:00:00	0	0.000	
5	1-Jan-19	0:00:00	1-Jan-19	0:00:00	0:00:00	0	0.000	
6	1-Jan-19	0:00:00	1-Jan-19	0:00:00	0:00:00	0	0.000	

					CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)					3.520	0.000	3.520
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)					3.520	0.000	3.520
PREVIOUS DAY ACTUAL RUNNING HOURS					86:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)					87:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)					72:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 2-Jan-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 123.44 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 16704 Cusec 41 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 18609 Cusec 46 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
17706	617

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
620	0	17953	18609	0	301



जल नियंत्रण - जल संयंत्र

for
Touseef Ali
02/01
AEE (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP-Asoj,Kasor,Raj-1,Raj-2 and Dhule-1 lines are in service at 10:00 hrs.

2. SSP SCO Running Details:

Unit No.1: 18:15 hrs on 01.01.19 to 05:45 hrs on 02.01.19.

Unit No.3: 19:00 hrs on 01.01.19 to 05:50 hrs on 02.01.19.

Unit No.6: 20:05 hrs on 01.01.19 to 06:20 hrs on 02.01.19.