



DAILY PLANT REPORT(DPR) OF Sardar Sarovar Project Power Houses
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 26-Jan-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 25-Jan-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	25-Jan-19	0:00 11:00	25-Jan-19	1:00 24:00	14:00:00	36.00	0.492	Today(i.e. 26.01.2019), 3 CHPH M/cs are running at 10:00 hrs.
2	25-Jan-19	11:25:00	25-Jan-19	23:30:00	12:05:00	36.00	0.420	
3	25-Jan-19	0:00:00	25-Jan-19	24:00:00	24:00:00	40.00	0.844	
4	25-Jan-19	0:00:00	25-Jan-19	24:00:00	24:00:00	38.00	0.906	
5	25-Jan-19	0:00:00	25-Jan-19	11:30:00	11:30:00	38.00	0.419	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	25-Jan-19	0:00:00	25-Jan-19	0:00:00	0:00:00	0	0.000	Today(i.e. 26.01.2019), no SSP-RBPH M/c is scheduled. SSP-RBPH Unit no.3 under AOH work from 22.01.2019.
2	25-Jan-19	0:00:00	25-Jan-19	0:00:00	0:00:00	0	0.000	
3	25-Jan-19	0:00:00	25-Jan-19	0:00:00	0:00:00	0	0.000	
4	25-Jan-19	0:00:00	25-Jan-19	0:00:00	0:00:00	0	0.000	
5	25-Jan-19	0:00:00	25-Jan-19	0:00:00	0:00:00	0	0.000	
6	25-Jan-19	0:00:00	25-Jan-19	0:00:00	0:00:00	0	0.000	

					CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)					3.081	0.000	3.081
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)					80.203	0.000	80.203
PREVIOUS DAY ACTUAL RUNNING HOURS					85:35:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)					85:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)					72:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 26-Jan-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 120.51 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 494 Cusec 1 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 18014 Cusec 44 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
17699	647

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
638	0	17555	18014	0	264



for *Touseef Ali* 26/1/19
AEE (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG. CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.
1. 400 kV SSP-Asoj, Kasor, Raj-1, and Dhule-2 lines are in service.

2. SSP SCO Running Details:

- Unit No.4: 14:10 hrs on 25.01.19 to 05:55 hrs on 26.01.19.
- Unit No.5: 14:20 hrs on 25.01.19 to 06:00 hrs on 26.01.19.
- Unit No.6: 21:40 hrs on 25.01.19 to 07:20 hrs on 26.01.19.