



DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 02-Jan-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 01-Jan-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	1-Jan-20	0:00:00	1-Jan-20	24:00:00	24:00:00	15.00	0.354	Today(i.e. 02.01.2020), 5 SSP-CHPH M/cs are running at 10:00 hrs.
2	1-Jan-20	0:00:00	1-Jan-20	24:00:00	24:00:00	15.00	0.355	
3	1-Jan-20	0:00:00	1-Jan-20	24:00:00	24:00:00	51.00	1.202	
4	1-Jan-20	0:00:00	1-Jan-20	24:00:00	24:00:00	52.00	1.240	
5	1-Jan-20	0:00:00	1-Jan-20	24:00:00	24:00:00	52.00	1.206	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	1-Jan-20	0:00:00	1-Jan-20	0:00:00	0:00:00	0	0.000	Today(i.e. 02.01.2020), 4 SSP-RBPH M/cs are running at 10:00 hrs. <u>Unit No. 2 under AOH from 24.12.2019.</u>
2	1-Jan-20	0:00:00	1-Jan-20	0:00:00	0:00:00	0	0.000	
3	1-Jan-20	5:45 15:00	1-Jan-20	11:15 18:00	8:30:00	203	1.718	
4	1-Jan-20	6:15:00	1-Jan-20	11:30:00	5:15:00	202	1.064	
5	1-Jan-20	6:30:00	1-Jan-20	12:00:00	5:30:00	202	1.112	
6	1-Jan-20	7:00 14:30	1-Jan-20	12:15 18:15	9:00:00	203	1.828	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	4.357	5.722	10.079
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	4.357	5.722	10.079
PREVIOUS DAY ACTUAL RUNNING HOURS	120:00:00	28:15:00	
TODAY'S DC (Schedule) Planned (in Hours)	120:00:00	29:30:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	120:00:00	27:00:00	

SSP hydrological data : at 08:00 Hrs on 2-Jan-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 133.29 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 14192 Cusec 35 MCM ✓
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 25133 Cusec 61 MCM ✓
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
18131	500

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
526	0	18179	17428	7705	463



(Signature)
AEE (EMC)
NCA, INDORE
21/1/2020

Copy to:

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Running Detail:

Unit No.4: 19:30 hrs on 01.01.2020 to 05:45 hrs on 02.01.2020.

Unit No.5: 21:10 hrs on 01.01.2020 to 05:50 hrs on 02.01.2020.