



**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	21-Jan-20	0:00:00	21-Jan-20	24:00:00	24:00:00	15.00	0.353	Today(i.e. 22.01.2020), 4 SSP-CHPH M/cs are running at 10:00 hrs.
2	21-Jan-20	0:00:00	21-Jan-20	24:00:00	24:00:00	15.00	0.353	
3	21-Jan-20	0:00:00	21-Jan-20	24:00:00	24:00:00	50.00	1.167	
4	21-Jan-20	0:00:00	21-Jan-20	24:00:00	24:00:00	50.00	1.202	
5	21-Jan-20	0:00:00	21-Jan-20	24:00:00	24:00:00	51.00	1.196	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	21-Jan-20	07:15 15:15	21-Jan-20	12:00 17:45	7:15:00	202	1.464	Today(i.e. 22.01.2020), 5 SSP-RBPH M/cs are running at 10:00 hrs.  RBPH Unit No. 3 is under AOH from 17.01.2020 to 06.02.2020
2	21-Jan-20	7:00 15:00	21-Jan-20	11:45 18:00	7:45:00	202	1.560	
3	21-Jan-20	0:00:00	21-Jan-20	0:00:00	0:00:00	0	0.000	
4	21-Jan-20	6:45 14:45	21-Jan-20	11:30 18:15	8:15:00	201	1.680	
5	21-Jan-20	6:30:00	21-Jan-20	18:45:00	12:15:00	203	2.488	
6	21-Jan-20	6:15:00	21-Jan-20	11:15:00	5:00:00	203	1.016	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	4.271	8.208	12.479
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	78.849	147.814	226.663
PREVIOUS DAY ACTUAL RUNNING HOURS	120:00:00	40:30:00	
TODAY'S DC (Schedule) Planned (in Hours)	101:00:00	42:15:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	41:00:00	

SSP hydrological data : at 08:00 Hrs on 22-Jan-20

**DATA RECEIVED FROM FLOOD CELL**

- RESERVOIR LEVEL IN Metres 131.09 Mtrs. ✓
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 12073 Cusec 30 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 29467 Cusec 72 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
17877	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
545	0	18482	17952	11515	416



AEE (EMC)  
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Running Detail: Nil

*(Signature)*  
22/1/2020