



(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	26-Jan-20	0:00:00	26-Jan-20	24:00:00	24:00:00	16.00	0.336	Today(i.e. 27.01.2020), 5 SSP-CHPH M/cs are running at 10:00 hrs.
2	26-Jan-20	0:00:00	26-Jan-20	24:00:00	24:00:00	15.00	0.352	
3	26-Jan-20	0:00:00	26-Jan-20	24:00:00	24:00:00	51.00	1.148	
4	26-Jan-20	0:00:00	26-Jan-20	24:00:00	24:00:00	53.00	1.222	
5	26-Jan-20	0:00:00	26-Jan-20	24:00:00	24:00:00	51.00	1.199	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	26-Jan-20	6:15:00	26-Jan-20	11:00:00	4:45:00	202	0.956	Today(i.e. 27.01.2020), 5 SSP-RBPH M/cs are running at 10:00 hrs. RBPH Unit No. 3 is under AOH from 17.01.2020 to 06.02.2020
2	26-Jan-20	6:30 14:30	26-Jan-20	11:15 17:45	8:00:00	202	1.622	
3	26-Jan-20	0:00:00	26-Jan-20	0:00:00	0:00:00	0	0.000	
4	26-Jan-20	6:45 14:45	26-Jan-20	11:30 18:00	8:00:00	203	1.632	
5	26-Jan-20	7:00 15:00	26-Jan-20	11:45 18:15	8:00:00	202	1.634	
6	26-Jan-20	7:15:00	26-Jan-20	18:30:00	11:15:00	203	2.270	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	4.257	8.114	12.371
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	99.871	189.296	289.167
PREVIOUS DAY ACTUAL RUNNING HOURS	120:00:00	40:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	120:00:00	42:45:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	120:00:00	42:15:00	

SSP hydrological data : at 08:00 Hrs on 27-Jan-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 130.47 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 27011 Cusec 66 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 29418 Cusec 72 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
19027	487

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
501	0	18998	18324	11094	405



(Signature)
AEE (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Running Detail:

Unit No.2: 18:25 hrs on 26.01.2020 to 05:45 hrs on 27.01.2020.

Unit No.5: 20:40 hrs on 26.01.2020 to 05:50 hrs on 27.01.2020.