



(CHPH 5X50 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUS | REMARKS |
|----------|-----------|---------|-----------|----------|-------------|----------------|-------------------|---|
| 1 | 28-Jan-20 | 0:00:00 | 28-Jan-20 | 24:00:00 | 24:00:00 | 15.00 | 0.348 | Today(i.e. 29.01.2020), 5 SSP-CHPH M/cs are running at 10:00 hrs. |
| 2 | 28-Jan-20 | 0:00:00 | 28-Jan-20 | 24:00:00 | 24:00:00 | 15.00 | 0.345 | |
| 3 | 28-Jan-20 | 0:00:00 | 28-Jan-20 | 24:00:00 | 24:00:00 | 49.00 | 1.163 | |
| 4 | 28-Jan-20 | 0:00:00 | 28-Jan-20 | 24:00:00 | 24:00:00 | 51.00 | 1.209 | |
| 5 | 28-Jan-20 | 0:00:00 | 28-Jan-20 | 24:00:00 | 24:00:00 | 51.00 | 1.208 | |

(RBPH 6X200 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUS | REMARKS |
|----------|-----------|----------------|-----------|----------------|-------------|----------------|-------------------|---|
| 1 | 28-Jan-20 | 06:15 14:45 | 28-Jan-20 | 11:30 18:45 | 9:15:00 | 203 | 1.862 | Today(i.e. 29.01.2020), 5 SSP-RBPH M/cs are running at 10:00 hrs. RBPH Unit No. 3 is under AOH from 17.01.2020 to 06.02.2020 |
| 2 | 28-Jan-20 | 06:30 15:00 | 28-Jan-20 | 11:45 18:35 | 8:50:00 | 203 | 1.784 | |
| 3 | 28-Jan-20 | 0:00:00 | 28-Jan-20 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 4 | 28-Jan-20 | 6:45:00 | 28-Jan-20 | 12:00:00 | 5:15:00 | 203 | 1.074 | |
| 5 | 28-Jan-20 | 07:00 15:15 | 28-Jan-20 | 12:15 18:10 | 8:10:00 | 202 | 1.656 | |
| 6 | 28-Jan-20 | 7:15:00 | 28-Jan-20 | 18:00:00 | 10:45:00 | 204 | 2.176 | |

| | CHPH (5 X 50MW) | RBPH (6X200 MW) | SSP(CHPH+RBPH) |
|--|-----------------|-----------------|----------------|
| GROSS GENERATION IN(MUs) | 4.273 | 8.552 | 12.825 |
| CUMMULATIVE GROSS GEN. FOR MONTH (MUs) | 108.399 | 206.486 | 314.885 |
| PREVIOUS DAY ACTUAL RUNNING HOURS | 120:00:00 | 42:15:00 | |
| TODAY'S DC (Schedule) Planned (in Hours) | 120:00:00 | 41:45:00 | |
| DAY AHEAD (TOMMORROW) DC (in Hours) | 120:00:00 | 40:15:00 | |

SSP hydrological data : at 08:00 Hrs on 29-Jan-20

DATA RECEIVED FROM FLOOD CELL.

- RESERVOIR LEVEL IN Metres 130.03 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 12679 Cusec 31 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 31027 Cusec 76 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

| HR | GODBOLE |
|-------|---------|
| 19053 | 0 |

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

| GODBOLE | OVER FLOW | HR | CHPH | RBPH | Ev. Loss |
|---------|-----------|-------|-------|-------|----------|
| 466 | 0 | 19503 | 18634 | 12393 | 399 |



(Signature)
29/1/20
AEE (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Running Detail:

Unit No.6: 20:05 hrs on 28.01.2020 to 05:45 hrs on 29.01.2020.

Unit No.4: 20:10 hrs on 28.01.2020 to 05:40 hrs on 29.01.2020.