



**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	29-Jan-20	0:00:00	29-Jan-20	24:00:00	24:00:00	15.00	0.357	Today(i.e. 30.01.2020), 5 SSP-CHPH M/cs are running at 10:00 hrs.
2	29-Jan-20	0:00:00	29-Jan-20	24:00:00	24:00:00	15.00	0.353	
3	29-Jan-20	0:00:00	29-Jan-20	24:00:00	24:00:00	50.00	1.179	
4	29-Jan-20	0:00:00	29-Jan-20	24:00:00	24:00:00	52.00	1.222	
5	29-Jan-20	0:00:00	29-Jan-20	24:00:00	24:00:00	51.00	1.205	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	29-Jan-20	06:00 14:30	29-Jan-20	11:15 19:00	9:45:00	204	1.972	Today(i.e. 30.01.2020), 5 SSP-RBPH M/cs are running at 10:00 hrs.  RBPH Unit No. 3 is under AOH from 17.01.2020 to 06.02.2020
2	29-Jan-20	06:15 14:45	29-Jan-20	11:30 19:15	9:45:00	204	1.972	
3	29-Jan-20	0:00:00	29-Jan-20	0:00:00	0:00:00	0	0.000	
4	29-Jan-20	6:30:00	29-Jan-20	11:45:00	5:15:00	202	1.070	
5	29-Jan-20	6:45:00	29-Jan-20	12:00:00	5:15:00	201	1.072	
6	29-Jan-20	7:00:00	29-Jan-20	18:45:00	11:45:00	204	2.378	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	4.316	8.464	12.780
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	112.715	214.950	327.665
PREVIOUS DAY ACTUAL RUNNING HOURS	120:00:00	41:45:00	
TODAY'S DC (Schedule) Planned (in Hours)	120:00:00	40:15:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	120:00:00	40:45:00	

SSP hydrological data : at 08:00 Hrs on 30-Jan-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 129.85 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 14069 Cusec 34 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 30545 Cusec 75 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
19502	466

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
484	0	19541	18767	11778	396



for showing  
30/1/20  
J. C. EMC, NCA

AEE (EMC)  
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Running Detail:

Unit No.1: 19:40hrs on 29.01.2020 to 05:45 hrs on 30.01.2020.