



DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 04-Jan-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 03-Jan-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	3-Jan-20	0:00:00	3-Jan-20	24:00:00	24:00:00	16.00	0.362	Today(i.e. 04.01.2020), 5 SSP-CHPH M/cs are running at 10:00 hrs.
2	3-Jan-20	0:00:00	3-Jan-20	24:00:00	24:00:00	16.00	0.359	
3	3-Jan-20	0:00:00	3-Jan-20	24:00:00	24:00:00	51.00	1.218	
4	3-Jan-20	0:00:00	3-Jan-20	24:00:00	24:00:00	52.00	1.236	
5	3-Jan-20	0:00:00	3-Jan-20	24:00:00	24:00:00	52.00	1.215	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	3-Jan-20	7:20 14:15	3-Jan-20	11:05 18:00	7:30:00	203	1.506	Today(i.e. 04.01.2020), 4 SSP-RBPH M/cs are running at 10:00 hrs. Unit No. 2 under AOH from 24.12.2019.
2	3-Jan-20	0:00:00	3-Jan-20	0:00:00	0:00:00	0	0.000	
3	3-Jan-20	6:30:00	3-Jan-20	11:15:00	4:45:00	203	0.956	
4	3-Jan-20	15:15:00	3-Jan-20	18:45:00	3:30:00	203	0.718	
5	3-Jan-20	7:00:00	3-Jan-20	11:45:00	4:45:00	202	0.964	
6	3-Jan-20	5:45:00	3-Jan-20	12:15:00	6:30:00	204	1.312	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	4.390	5.456	9.846
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	13.131	17.136	30.267
PREVIOUS DAY ACTUAL RUNNING HOURS	120:00:00	27:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	120:00:00	27:15:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	120:00:00	26:45:00	

SSP hydrological data : at 08:00 Hrs on 4-Jan-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 133.12 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 13884 Cusec 34 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 24829 Cusec 61 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
18179	520

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
460	0	18488	17603	7226	459



for: **Ashita Kaur**
J. E. (Elect.)
EMC, NCA
AEE (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Running Detail:

Unit No.5: 19:55 hrs on 03.01.2020 to 05:40 hrs on 04.01.2020.

Unit No.6: 20:00 hrs on 03.01.2020 to 05:35 hrs on 04.01.2020.