



DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 05-Jan-20  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 04-Jan-20

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	4-Jan-20	0:00:00	4-Jan-20	24:00:00	24:00:00	15.00	0.361	Today(i.e. 05.01.2020), 5 SSP-CHPH M/cs are running at 10:00 hrs.
2	4-Jan-20	0:00:00	4-Jan-20	24:00:00	24:00:00	15.00	0.355	
3	4-Jan-20	0:00:00	4-Jan-20	24:00:00	24:00:00	52.00	1.226	
4	4-Jan-20	0:00:00	4-Jan-20	24:00:00	24:00:00	52.00	1.235	
5	4-Jan-20	0:00:00	4-Jan-20	24:00:00	24:00:00	51.00	1.210	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	4-Jan-20	6:00 14:45	4-Jan-20	11:00 18:45	9:00:00	203	1.814	Today(i.e. 05.01.2020), 4 SSP-RBPH M/cs are running at 10:00 hrs.  <b>Unit No. 2 under AOH from 24.12.2019.</b>
2	4-Jan-20	0:00:00	4-Jan-20	0:00:00	0:00:00	0	0.000	
3	4-Jan-20	6:30:00	4-Jan-20	11:15:00	4:45:00	203	0.954	
4	4-Jan-20	7:00:00	4-Jan-20	11:45:00	4:45:00	202	0.960	
5	4-Jan-20	14:15:00	4-Jan-20	18:00:00	3:45:00	203	0.764	
6	4-Jan-20	7:15:00	4-Jan-20	12:15:00	5:00:00	203	1.010	

		CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)		4.387	5.502	9.889
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)		17.518	22.638	40.156
PREVIOUS DAY ACTUAL RUNNING HOURS		120:00:00	27:15:00	
TODAY'S DC (Schedule) Planned (in Hours)		120:00:00	26:45:00	
DAY AHEAD (TOMMORROW) DC (in Hours)		120:00:00	26:45:00	

SSP hydrological data : at 08:00 Hrs on 5-Jan-20

**DATA RECEIVED FROM FLOOD CELL**

- RESERVOIR LEVEL IN Metres 133.00 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 10499 Cusec 26 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 25248 Cusec 62 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
18488	460

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
489	0	18113	17752	7496	456



for  
05/01/20

AEE (EMC)  
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member(Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG CE(E&M), SSNNL, Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Running Detail:

Unit No.6: 20:00 hrs on 04.01.2020 to 06:15 hrs on 05.01.2020.

Unit No.5: 20:10 hrs on 04.01.2020 to 06:05 hrs on 05.01.2020.