



(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	6-Jan-20	0:00:00	6-Jan-20	0:00:00	0:00:00	0.00	0.000	Today(i.e. 07.01.2020), 4 SSP-CHPH M/cs are running at 10:00 hrs.
2	6-Jan-20	0:00:00	6-Jan-20	24:00:00	24:00:00	15.00	0.358	
3	6-Jan-20	0:00:00	6-Jan-20	24:00:00	24:00:00	51.00	1.204	
4	6-Jan-20	0:00:00	6-Jan-20	24:00:00	24:00:00	52.00	1.203	
5	6-Jan-20	0:00:00	6-Jan-20	24:00:00	24:00:00	52.00	1.186	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	6-Jan-20	14:30:00	6-Jan-20	18:15:00	3:45:00	203	0.762	Today(i.e. 07.01.2020), 4 SSP-RBPH M/cs are running at 10:00 hrs. <u>Unit No. 2 under AOH from 24.12.2019.</u>
2	6-Jan-20	0:00:00	6-Jan-20	0:00:00	0:00:00	0	0.000	
3	6-Jan-20	7:00:00	6-Jan-20	12:00:00	5:00:00	203	1.004	
4	6-Jan-20	6:00:00	6-Jan-20	11:45:00	5:45:00	204	1.162	
5	6-Jan-20	6:30:00	6-Jan-20	11:15:00	4:45:00	202	0.962	
6	6-Jan-20	07:15 14:45	6-Jan-20	11:00 18:30	7:30:00	203	1.518	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	3.951	5.408	9.359
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	25.799	33.462	59.261
PREVIOUS DAY ACTUAL RUNNING HOURS	96:00:00	26:45:00	
TODAY'S DC (Schedule) Planned (in Hours)	96:00:00	27:30:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	27:15:00	

SSP hydrological data : at 08:00 Hrs on 7-Jan-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 132.83 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 13833 Cusec 34 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 23519 Cusec 58 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
16730	549

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	16749	16290	7229	451



जल धरत जल राखत

(Signature)
7/1/2020
AEE (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Running Detail:

Unit No.5: 21:30 hrs on 06.01.2020 to 06:50 hrs on 07.01.2020.

Unit No.4: 21:35 hrs on 06.01.2020 to 06:45 hrs on 07.01.2020.