



(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	7-Jan-20	0:00:00	7-Jan-20	0:00:00	0:00:00	0.00	0.000	Today(i.e. 08.01.2020), 4 SSP-CHPH M/cs are running at 10:00 hrs.
2	7-Jan-20	0:00:00	7-Jan-20	23:00:00	23:00:00	15.00	0.342	
3	7-Jan-20	0:00:00	7-Jan-20	24:00:00	24:00:00	51.00	1.201	
4	7-Jan-20	0:00:00	7-Jan-20	24:00:00	24:00:00	51.00	1.213	
5	7-Jan-20	0:00:00	7-Jan-20	24:00:00	24:00:00	51.00	1.182	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	7-Jan-20	06:30 14:30	7-Jan-20	11:00 17:45	7:45:00	203	1.566	Today(i.e. 08.01.2020), 4 SSP-RBPH M/cs are running at 10:00 hrs. Unit No. 2 under AOH from 24.12.2019.
2	7-Jan-20	0:00:00	7-Jan-20	0:00:00	0:00:00	0	0.000	
3	7-Jan-20	07:00 14:45	7-Jan-20	11:15 20:00	9:30:00	205	1.922	
4	7-Jan-20	0:00:00	7-Jan-20	0:00:00	0:00:00	0	0.000	
5	7-Jan-20	7:15:00	7-Jan-20	12:00:00	4:45:00	201	0.962	
6	7-Jan-20	6:45:00	7-Jan-20	12:15:00	5:30:00	202	1.114	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	3.938	5.564	9.502
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	29.737	39.026	68.763
PREVIOUS DAY ACTUAL RUNNING HOURS	95:00:00	27:30:00	
TODAY'S DC (Schedule) Planned (in Hours)	96:00:00	27:15:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	27:45:00	

SSP hydrological data : at 08:00 Hrs on 8-Jan-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 132.81 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 21133 Cusec 52 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 23217 Cusec 57 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
16749	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
578	0	16002	15780	7437	450



जल संचयन - जल संयम

for Shree...
8/1/19
JE, ENGR, NCA

AEE (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Running Detail:

Unit No.5: 22:05 hrs on 07.01.2020 to 04:20 hrs on 08.01.2020.

Unit No.6: 22:15 hrs on 07.01.2020 to 04:25 hrs on 08.01.2020.

3. Correction in Godbole discharge.