



(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	31-Dec-20	0:00:00	31-Dec-20	24:00:00	24:00:00	51.00	1.195	Today (i.e. 01.01.2021), 4 SSP-CHPH M/cs are running at 10:00 hrs. Unit No. 2 is under L/C from 29.12.2020.
2	31-Dec-20	0:00:00	31-Dec-20	0:00:00	0:00:00	0.00	0.000	
3	31-Dec-20	0:00:00	31-Dec-20	24:00:00	24:00:00	51.00	1.201	
4	31-Dec-20	0:00:00	31-Dec-20	24:00:00	24:00:00	51.00	1.216	
5	31-Dec-20	0:00:00	31-Dec-20	24:00:00	24:00:00	51.00	1.190	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	31-Dec-20	6:30:00	31-Dec-20	11:15:00	4:45:00	205	0.972	Today(i.e. 01.01.2021), 4 SSP-RBPH M/c are running at 10:00 hrs. Unit No. 2 is under A.O.H. from 24.12.2020.
2	31-Dec-20	0:00:00	31-Dec-20	0:00:00	0:00:00	0	0.000	
3	31-Dec-20	6:45:00	31-Dec-20	11:30:00	4:45:00	205	0.968	
4	31-Dec-20	0:00:00	31-Dec-20	0:00:00	0:00:00	0	0.000	
5	31-Dec-20	7:00:00	31-Dec-20	11:45:00	4:45:00	204	0.970	
6	31-Dec-20	7:15:00	31-Dec-20	12:00:00	4:45:00	205	0.976	

		CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)		4.802	3.886	8.688
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)		138.566	103.602	242.168
PREVIOUS DAY ACTUAL RUNNING HOURS		96:00:00	19:00:00	
TODAY'S DC (Schedule) Planned (in Hours)		96:00:00	19:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)		96:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 1-Jan-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 133.95 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 21182 Cusec 51.82 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 23245 Cusec 56.87 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
21130	638

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
611	0	20486	18303	4942	472



[Signature]
11/1/2021
AEE (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Details:

Unit No.3: 19:20Hrs on 31.12.2020 to 05:15Hrs on 01.01.2021.

Unit No.4: 19:25Hrs on 31.12.2020 to 05:40Hrs on 01.01.2021.

Unit No.5: 20:00Hrs on 31.12.2020 to 05:45 Hrs on 01.01.2021.