



DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 15-Jan-21
ISSUE TIME: 10:00 Hrs
FOR DATE: 14-Jan-21

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	14-Jan-21	0:00:00	14-Jan-21	24:00:00	24:00:00	50.00	1.199	Today (i.e. 15.01.2021), 3 SSP-CHPH M/cs are running at 10:00 hrs.
2	14-Jan-21	0:00:00	14-Jan-21	24:00:00	24:00:00	51.00	1.204	
3	14-Jan-21	0:00:00	14-Jan-21	24:00:00	24:00:00	51.00	1.215	
4	14-Jan-21	0:00:00	14-Jan-21	0:00:00	0:00:00	0.00	0.000	
5	14-Jan-21	13:00:00	14-Jan-21	24:00:00	11:00:00	51.00	0.548	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	14-Jan-21	8:00:00	14-Jan-21	11:30:00	3:30:00	205	0.718	Today (i.e. 15.01.2021), 4 SSP-RBPH M/cs are running at 10:00 hrs. Unit No.3 will be under AOH from 16.01.2021
2	14-Jan-21	0:00:00	14-Jan-21	0:00:00	0:00:00	0	0.000	
3	14-Jan-21	0:00:00	14-Jan-21	0:00:00	0:00:00	0	0.000	
4	14-Jan-21	0:00:00	14-Jan-21	0:00:00	0:00:00	0	0.000	
5	14-Jan-21	7:30:00	14-Jan-21	12:00:00	4:30:00	204	0.922	
6	14-Jan-21	7:45:00	14-Jan-21	11:45:00	4:00:00	205	0.818	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	4.166	2.458	6.624
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	62.682	44.982	107.664
PREVIOUS DAY ACTUAL RUNNING HOURS	83:00:00	12:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	12:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	16:00:00	

SSP hydrological data : at 08:00 Hrs on 15-Jan-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 133.92 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 27162 Cusec 66.45 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 20347 Cusec 49.78 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
18509	618

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
620	0	18766	16867	3480	479



[Signature]
15/1/21
AEE (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Details:

Unit No.5: 13:45 Hrs on 14.01.2021 to 05:45 Hrs on 16.01.2021.

Unit No.6: 13:55 Hrs on 14.01.2021 to 05:40 Hrs on 16.01.2021.