



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 30-Jan-21

ISSUE TIME: 10:00 Hrs

FOR DATE: 29-Jan-21

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	29-Jan-21	0:00:00	29-Jan-21	24:00:00	24:00:00	51.00	1.199	Today (i.e. 30.01.2021), 3 SSP-CHPH M/cs are running at 10:00 hrs.
2	29-Jan-21	0:00:00	29-Jan-21	0:00:00	0:00:00	0.00	0.000	
3	29-Jan-21	0:00:00	29-Jan-21	24:00:00	24:00:00	51.00	1.200	
4	29-Jan-21	0:00:00	29-Jan-21	24:00:00	24:00:00	51.00	1.220	
5	29-Jan-21	7:15 22:30	29-Jan-21	19:00 24:00	13:15:00	50.00	0.651	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	29-Jan-21	7:45:00	29-Jan-21	11:30:00	3:45:00	202	0.754	Today (i.e. 30.01.2021), 4 SSP-RBPH M/cs are running at 10:00 hrs. Unit No.3 is under AOH from 16.01.2021
2	29-Jan-21	8:00:00	29-Jan-21	11:45:00	3:45:00	203	0.762	
3	29-Jan-21	0:00:00	29-Jan-21	0:00:00	0:00:00	0	0.000	
4	29-Jan-21	0:00:00	29-Jan-21	0:00:00	0:00:00	0	0.000	
5	29-Jan-21	7:15:00	29-Jan-21	12:00:00	4:45:00	202	0.966	
6	29-Jan-21	7:30:00	29-Jan-21	11:15:00	3:45:00	204	0.764	

		CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)		4.270	3.246	7.516
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)		128.311	99.714	228.025
PREVIOUS DAY ACTUAL RUNNING HOURS		85:15:00	16:00:00	
TODAY'S DC (Schedule) Planned (in Hours)		72:00:00	16:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)		72:00:00	16:00:00	

SSP hydrological data : at 08:00 Hrs on 30-Jan-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 133.60 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 18829 Cusec 46.07 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 23425 Cusec 57.31 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
18492	618

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
612	0	18984	18801	4624	471



for Archita Kamnager
J.E. (Elect.)
30.01.2021
EE (EMC)
NCA, INDORE

Copy to:

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member(Power), NVDA, Bhopal

GoMah. CE, WRD, Mumbai

GoG. CE(E&M), SSNNL, Vadodra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Details:

Unit No.5: 19:00 Hrs on 29.01.2021 to 06:50 Hrs on 30.01.2021.

Unit No.6: 19:10 Hrs on 29.01.2021 to 06:55 Hrs on 30.01.2021.