



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 05-Jan-21
ISSUE TIME: 10:00 Hrs
FOR DATE: 04-Jan-21

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	4-Jan-21	0:00:00	4-Jan-21	24:00:00	24:00:00	51.00	1.206	Today (i.e. 05.01.2021), 4 SSP-CHPH M/cs are running at 10:00 hrs.
2	4-Jan-21	22:21:00	4-Jan-21	24:00:00	1:39:00	50.00	0.075	
3	4-Jan-21	0:00:00	4-Jan-21	24:00:00	24:00:00	51.00	1.207	
4	4-Jan-21	0:00:00	4-Jan-21	24:00:00	24:00:00	51.00	1.214	
5	4-Jan-21	0:00:00	4-Jan-21	22:50:00	22:50:00	51.00	1.127	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	4-Jan-21	7:15:00	4-Jan-21	11:15:00	4:00:00	204	0.816	Today(i.e. 05.01.2021), 4 SSP-RBPH M/c are running at 10:00 hrs. Unit No. 2 is under A.O.H. from 24.12.2020.
2	4-Jan-21	0:00:00	4-Jan-21	0:00:00	0:00:00	0	0.000	
3	4-Jan-21	7:30:00	4-Jan-21	11:30:00	4:00:00	204	0.818	
4	4-Jan-21	7:45:00	4-Jan-21	11:45:00	4:00:00	204	0.818	
5	4-Jan-21	0:00:00	4-Jan-21	0:00:00	0:00:00	0	0.000	
6	4-Jan-21	8:00:00	4-Jan-21	12:00:00	4:00:00	204	0.814	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	4.829	3.266	8.095
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	18.960	13.082	32.042
PREVIOUS DAY ACTUAL RUNNING HOURS	96:29:00	16:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	101:30:00	16:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	16:00:00	

SSP hydrological data : at 08:00 Hrs on 5-Jan-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 133.88 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 19904 Cusec 48.70 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 24493 Cusec 59.92 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
20956	606

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
613	0	21555	19725	4768	479



[Signature]
5/1/21
AEE (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member(Power), NVDA, Bhopal

GoMah. CE, WRD, Mumbai

GoG CE(E&M), SSNNL, Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Details:

Unit No.4: 18:10 Hrs on 04.01.2021 to 05:55 Hrs on 05.01.2021.

Unit No.5: 18:20 Hrs on 04.01.2021 to 05:50 Hrs on 05.01.2021.

Unit No.6: 21:40 Hrs on 04.01.2021 to 05:45 Hrs on 05.01.2021.