

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 1-Jul-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 30-Jun-20

Daily Plant Report
(00:00 Hrs to 24:00Hrs.)

Date: 1-Jul-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	30-Jun-20	0:00:00	30-Jun-20	0:00:00	0:00:00	0.00	0.000	Today (i.e.01.07.2020) 3 SSP-CHPH M/cs are running at 10:00 hrs.
2	30-Jun-20	0:00:00	30-Jun-20	0:00:00	0:00:00	0.00	0.000	
3	30-Jun-20	0:00 15:30	30-Jun-20	15:16 24:00	23:46:00	40.00	0.937	
4	30-Jun-20	0:00:00	30-Jun-20	24:00:00	24:00:00	41.00	0.974	
5	30-Jun-20	0:00 17:45	30-Jun-20	13:00 24:00	19:15:00	40.00	0.762	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	30-Jun-20	0:00:00	30-Jun-20	24:00:00	24:00:00	168	3.978	Today(i.e. 01.07.2020), 6 SSP-RBPH M/cs are running at 10:00 hrs.
2	30-Jun-20	0:00:00	30-Jun-20	24:00:00	24:00:00	167	3.954	
3	30-Jun-20	0:00:00	30-Jun-20	24:00:00	24:00:00	167	3.964	
4	30-Jun-20	0:00:00	30-Jun-20	24:00:00	24:00:00	168	4.002	
5	30-Jun-20	0:00:00	30-Jun-20	24:00:00	24:00:00	164	3.924	
6	30-Jun-20	0:00:00	30-Jun-20	24:00:00	24:00:00	168	3.976	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	2.673	23.798	26.471
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	58.885	402.768	461.653
PREVIOUS DAY ACTUAL RUNNING HOURS	67:01:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	48:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 1-Jul-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 122.26 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 18874 Cusec 46 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 53352 Cusec 131 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
15352	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	15050	13269	40083	325



Copy to :

AEE (EMC)
NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2 Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condensor mode to control high voltage condition as per instruction of WRLDC respectively. The details:
