



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 11-Jul-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 10-Jul-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	10-Jul-20	0:00:00	10-Jul-20	0:00:00	0:00:00	0.00	0.000	Unit No. 1 is under L/C for runner blade inspection work. Today (i.e.11.07.2020) 2 SSP-CHPH M/cs are running at 10:00 hrs.
2	10-Jul-20	0:00:00	10-Jul-20	0:00:00	0:00:00	0.00	0.000	
3	10-Jul-20	16:00:00	10-Jul-20	24:00:00	8:00:00	38.00	0.296	
4	10-Jul-20	0:00:00	10-Jul-20	24:00:00	24:00:00	39.00	0.911	
5	10-Jul-20	0:00:00	10-Jul-20	23:30:00	23:30:00	37.00	0.853	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	10-Jul-20	0:00:00	10-Jul-20	2:45:00	2:45:00	189	0.530	Today(i.e. 11.07.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs.
2	10-Jul-20	0:00:00	10-Jul-20	2:30:00	2:30:00	189	0.470	
3	10-Jul-20	0:00:00	10-Jul-20	2:15:00	2:15:00	189	0.424	
4	10-Jul-20	0:00:00 5:15 14:30	10-Jul-20	2:00 8:45 20:30	11:30:00	195	2.232	
5	10-Jul-20	0:00:00	10-Jul-20	0:00:00	0:00:00	0	0.000	
6	10-Jul-20	0:00:00	10-Jul-20	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	2.060	3.656	5.716
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	16.988	88.560	105.548
PREVIOUS DAY ACTUAL RUNNING HOURS	55:30:00	19:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	48:00:00	19:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	16:30:00	

SSP hydrological data : at 08:00 Hrs on 11-Jul-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 121.63 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 11054 Cusec 27 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 17522 Cusec 43 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
10293	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	11563	11799	5723	197



For Archita Kamnig 11.07.2020

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.
1. 400 kV SSP Asoj, Kasor, Dhule-1, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

Unit No.5:20:35 hrs on 10:07.2020 to 06:45 Hrs on 11.07.2020.

Unit No.6: 20:45hrs on 10:07.2020 to 06:50 Hrs on 11.07.2020

AEE (EMC)
NCA, INDORE