



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 12-Jul-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 11-Jul-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	11-Jul-20	0:00:00	11-Jul-20	0:00:00	0:00:00	0.00	0.000	Unit No. 1 is under L/C for runner blade inspection work. Today (i.e.12.07.2020) 2 SSP-CHPH M/cs are running at 10:00 hrs.
2	11-Jul-20	0:00:00	11-Jul-20	0:00:00	0:00:00	0.00	0.000	
3	11-Jul-20	0:00:00	11-Jul-20	24:00:00	24:00:00	38.00	0.881	
4	11-Jul-20	0:00:00	11-Jul-20	24:00:00	24:00:00	39.00	0.910	
5	11-Jul-20	18:00:00	11-Jul-20	24:00:00	6:00:00	38.00	0.217	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	11-Jul-20	0:15:00	11-Jul-20	2:15:00	2:00:00	195	0.392	Today (i.e. 12.07.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs.
2	11-Jul-20	0:00:00	11-Jul-20	2:30:00	2:30:00	194	0.486	
3	11-Jul-20	0:00:00	11-Jul-20	0:00:00	0:00:00	0	0.000	
4	11-Jul-20	00:00 18:45	11-Jul-20	8:30 22:15	12:00:00	197	2.372	
5	11-Jul-20	0:00:00	11-Jul-20	0:00:00	0:00:00	0	0.000	
6	11-Jul-20	0:00:00	11-Jul-20	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	2.008	3.250	5.258
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	18.996	91.810	110.806
PREVIOUS DAY ACTUAL RUNNING HOURS	54:00:00	16:30:00	
TODAY'S DC (Schedule) Planned (in Hours)	48:00:00	12:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	10:45:00	

SSP hydrological data : at 08:00 Hrs on 12-Jul-20

DATA RECEIVED FROM FLOOD CELL.

- RESERVOIR LEVEL IN Metres 121.52 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 7668 Cusec 19 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 15617 Cusec 38 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
11563	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	11698	11634	3983	196



for
12/07/20

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG. CE(E&M),SSNNL,Vadoadra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condensor mode to control high voltage condition as per instruction of WRLDC respectively. The details:

Unit No.5:18:10 hrs on 11:07.2020 to running on 12.07.2020.

Unit No.6: 18:20 hrs on 11:07.2020 to running on 12.07.2020

AEE (EMC)
NCA, INDORE