



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 14-Jul-20  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 13-Jul-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	13-Jul-20	0:00:00	13-Jul-20	0:00:00	0:00:00	0.00	0.000	Unit No. 1 is under L/C for runner blade inspection work. Today (i.e.14.07.2020) 2 SSP-CHPH M/cs are running at 10:00 hrs.
2	13-Jul-20	0:00:00	13-Jul-20	0:00:00	0:00:00	0.00	0.000	
3	13-Jul-20	17:00:00	13-Jul-20	24:00:00	7:00:00	38.00	0.256	
4	13-Jul-20	0:00:00	13-Jul-20	24:00:00	24:00:00	39.00	0.916	
5	13-Jul-20	0:00:00	13-Jul-20	24:00:00	24:00:00	37.00	0.868	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	13-Jul-20	0:00:00	13-Jul-20	0:00:00	0:00:00	0	0.000	Today(i.e. 14.07.2020), 0 SSP-RBPH M/cs is running at 10:00 hrs.
2	13-Jul-20	0:00:00	13-Jul-20	7:30:00	7:30:00	196	1.454	
3	13-Jul-20	0:00:00	13-Jul-20	0:00:00	0:00:00	0	0.000	
4	13-Jul-20	0:00:00	13-Jul-20	0:00:00	0:00:00	0	0.000	
5	13-Jul-20	0:00:00	13-Jul-20	0:00:00	0:00:00	0	0.000	
6	13-Jul-20	0:00:00	13-Jul-20	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	2.040	1.454	3.494
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	23.047	95.582	118.629
PREVIOUS DAY ACTUAL RUNNING HOURS	55:00:00	7:30:00	
TODAY'S DC (Schedule) Planned (in Hours)	48:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 14-Jul-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 121.22 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 1650 Cusec 4 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 11824 Cusec 29 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
12737	0

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	12631	11824	0	194



for Archita Kharunge  
14/7/2020  
AEE (EMC)  
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 KV SSP Asoj, Kasor, Dhule-1, Dhule 2, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

Unit No.3: 18:05 hrs on 13.07.2020 to 07:25 Hrs on 14.07.2020.

Unit No.5: 17:55hrs on 13.07.2020 to 07:30 Hrs on 14.07.2020