



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 18-Jul-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 17-Jul-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN Mus	REMARKS
1	17-Jul-20	0:00:00	17-Jul-20	0:00:00	0:00:00	0.00	0.000	Unit No. 1 is under L/C for runner blade inspection work. Today (i.e.18.07.2020) 3SSP-CHPH M/cs are running at 10:00 hrs.
2	17-Jul-20	0:00:00	17-Jul-20	0:00:00	0:00:00	0.00	0.000	
3	17-Jul-20	00:00:00 12:00	17-Jul-20	02:30:00 24:00	14:30:00	37.00	0.530	
4	17-Jul-20	0:00:00	17-Jul-20	24:00:00	24:00:00	38.00	0.898	
5	17-Jul-20	0:00:00	17-Jul-20	24:00:00	24:00:00	37.00	0.852	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN Mus	REMARKS
1	17-Jul-20	0:00:00	17-Jul-20	0:00:00	0:00:00	0	0.000	Today(i.e. 18.07.2020), 0 SSP-RBPH M/cs is running at 10:00 hrs.
2	17-Jul-20	0:00:00	17-Jul-20	0:00:00	0:00:00	0	0.000	
3	17-Jul-20	0:00:00	17-Jul-20	0:00:00	0:00:00	0	0.000	
4	17-Jul-20	0:00:00	17-Jul-20	0:00:00	0:00:00	0	0.000	
5	17-Jul-20	0:00:00	17-Jul-20	0:00:00	0:00:00	0	0.000	
6	17-Jul-20	0:00:00	17-Jul-20	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	2.280	0.000	2.280
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	32.268	95.582	127.850
PREVIOUS DAY ACTUAL RUNNING HOURS	62:30:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	48:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 18-Jul-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 121.09 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 10792 Cusec 26 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 12822 Cusec 31 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
14212	635

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
465	0	13073	12822	0	192



708 Archita Kawar 18.7.2020
AEE (EMC)
NCA, INDORE

Copy to:

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2. Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

Unit No.4: 19:00 hrs on 17.07.2020 to 06:35 Hrs on 18.07.2020.

Unit No.5: 18:50 hrs on 17.07.2020 to 06:40 Hrs on 18.07.2020.